

HAZCHECK AND THE DEVELOPMENT OF MAJOR INCIDENTS

G L WELLS and C PHANG (University of Sheffield, Sheffield, UK)

A B REEVES (AEA Technology, Culcheth, UK)

The events which build up into the occurrence of a major incident have been classified and programmed within a small database. This serves as a crude but structured checklist, termed HAZCHECK, which is available for use on an IBM compatible personal computer.

Much effort has been put into the establishing of a consistent nomenclature and the clear distinction between root or basic causes of an incident and the immediate causes which initiate a particular chain of events.

ROOT CAUSE, MAJOR INCIDENTS, AUDITS

THE DEVELOPMENT OF MAJOR INCIDENTS

A major process incident has its origins in root or basic causes and develops by the scenario illustrated in Figure 1.

Such an incident has the potential to cause major distress, hospitalize individuals, cause death to susceptible individuals and damage the environment. Apparently it is initiated by an immediate cause and progresses along the primary event chain summarised in Table 1. This table does not repeat the interconnections noted above. Adherence to rigid definitions of immediate and root causes and avoiding terms such as intermediate cause to define loss of protection leads to a better definition of the accident scenario for investigation purposes, design and the evaluation of risk.

The event chain shows how incidents develop. For general study of the frequency of occurrence of events it is desirable to estimate how often specific deviations and disturbances normally occur. This can be done with confidence only for the main events of each major accident involving a fatality or serious injury. So in the absence of appropriate additional data it is only possible to postulate that something like a million root causes of problems and disturbances might arise for every major incident, as suggested in Figure 3.

Such figures show that it is impractical to eliminate all causes of failures and discharge. They can only be reduced by constant vigilance. It is also clear from plotting the traditional range of hazard identification and evaluation techniques that not one of these covers the range of events particularly well, see Figure 4. Clearly root causes, see figure 2, are not readily identified by top-down studies but must be reduced using a bottom-up strategy and good practice.

TABLE 1 - The Primary Event Chain

DAMAGE OR HARM TO PEOPLE, PLANT, BUSINESS AND ENVIRONMENT

Harm to environment and people
 Damage to plant and property
 Impact on business
 Incident which is a near-miss

ESCALATING EVENTS AND FAILURE OF MITIGATION

Inadequate post-accident response
 Inadequate emergency response
 Countermeasures inadequate
 Secondary escalation by explosion, fire or toxic release
 Escalation by toxic release
 Escalation by explosion
 Escalation by fire

UNPLANNED RELEASE OF MATERIAL

Loss of significant process material
 Rupture on exceeding mechanical design limitations
 Equipment rupture due to defective or deteriorated construction
 Material lost through abnormal opening to atmosphere
 Loss on change in a planned discharge or vent

FAILURE TO CONTROL THE SITUATION

Emergency control systems fail to control the situation
 Operators fail to control the situation
 Normal control systems fail to control the situation
 Maintenance fails to control the situation

PLANT IN DANGEROUS STATE

Dangerous trend in operating conditions
 Construction defective or deteriorated in service
 Abnormal opening in equipment
 Change in a planned discharge or vent

IMMEDIATE CAUSES OF FAILURE AND DISCHARGE

Inadequate action by operator, maintenance or other personnel
 Plant, equipment or facilities inadequate or inoperable
 Control or emergency control inadequate or inoperable
 Defects directly causing loss of plant integrity
 Change from design intent
 Environmental and external cause

ROOT CAUSES OF FAILURE AND DISCHARGE

Inadequate maintenance
 Inadequate transport of materials
 Inadequate engineering and plant realisation
 Inadequate process design and knowhow
 Use of inappropriate or inadequate procedures
 Inadequate or wrong information, transfer and processing
 Personnel inadequate in task
 Inadequate capabilities of management and organisation
 Change in process requirements and external threats

ROOT CAUSES OF FAILURE AND DISCHARGE

Root causes generally represent conditions, capabilities and practices which fall below standards. They are identified in Table 2 and illustrated in Figure 2. They affect all immediate causes, all actions to control the situation and all mitigating actions. It is convenient to classify inadequate engineering and plant realisation as a basic cause.

TABLE 2 - Root Causes

Inadequate Engineering, Plant Realisation and Maintenance

Inadequate maintenance
 Inadequate commissioning and realisation
 Inadequate construction
 Inadequate manufacture/assembly
 Inadequate safety reviews and plans
 Inadequate site and plant layout
 Inadequate transport of materials
 Inadequate detailed engineering
 Inadequate engineering standards and specifications

Use of Inappropriate or Inadequate Procedures

Inadequate or faulty procedures
 Inadequate working practices
 Procedures difficult to follow
 Inadequate specification of task
 Absence or inadequate introduction of procedure
 Adverse extrinsic task factors
 Adverse intrinsic task factors

Personnel Inadequate in Task

Improper and inadvertent actions
 Adverse physiological state
 Inadequate quality and character
 Task overload of personnel
 Personnel absent or incapacitated
 Inadequate training and rehearsal
 Inadequate man-machine interface
 Inadequate operating environment

Change in Process Requirements and external threats

Change from specified process use
 Operational change
 Failure to manage change
 Disturbance from other systems
 Extreme environmental and external causes including sabotage

Inadequate Process Design

Inadequate operating instructions
 Inadequate contingency measures
 Inadequate emergency control systems
 Inadequate control/operability
 Inadequate preliminary evaluation
 Lack of consideration of states
 Excessive process discharges
 Excessive inventory and severe operating conditions
 Inadequate development and design
 Inadequate process knowhow

Inadequate Information, Transfer and Information Processing

Inadequate or wrong information
 Inadequate information processing
 Faulty problem solving, decision-making and risk-taking
 Incorrect response to information
 Loss of meaning on communication
 Inadequate channels of communication
 Inadequate information transfer

Inadequate Capabilities of Management and Organisation

Inadequate management abilities
 Failure to direct and coordinate
 Inadequate safety leadership
 Inadequate corporate management
 Inadequate technological experience
 Inadequate supervision & management
 Inadequate provision of resources
 Inadequate human resource management
 Inadequate facilities and site
 Inadequate procedures and standards
 Adverse organisational factors and corporate culture
 Inadequate response to change
 Failure to identify or monitor the capabilities of the firm
 Inadequate corporate strategies and tactics

IMMEDIATE CAUSES OF FAILURE AND DISCHARGE

The immediate causes of incidents are seen as the initiating events. They are given in Table 3. Inadequate action by personnel can be broken down according to the conventional job descriptions of operators, etc. Human failure or error is normally used in such a context but all too readily is inferred as to imply blame. The root cause of the incident is wherein blame probably lies. Change from the design intent is a helpful term with its link to inadequate management and organisational capabilities. Environmental and external cause are often significant only because of faults in the engineering design although obviously deliberate sabotage can be hard to prevent.

TABLE 3 - Immediate Causes

Inadequate Action by Operator Maintenance or Other Personnel	Defects Directly Causing Loss of Integrity
Failure to process information check or report Action based on inadequate or incorrect information Action not stimulated, not taken or omitted Action or check generating inadequate information or response	Defective or missing components Inadequate inspection Failure to detect defects prior to start-up Failure to support plant correctly Incorrect construction/installation Construction causes stresses/cracks Defective manufacture or assembly Incorrect or flawed joints, welds seals, packing, etc Incorrect or flawed materials
Process, Equipment, or Other Facilities Inadequate or Inoperable	Change From Design Intent
Sudden failure of equipment Gradual or partial failure incipient failure Use of facilities ignored Faulty information, transfer or processing Design functional deficiencies Inadequate installation Failure unavailable for use	Use of equipment for purposes and conditions outside those specified Incorrect modification from design intent during plant realisation Incorrect modification or other change particularly during maintenance Incorrect supply of raw materials and services
Control System Inadequate or Inoperable	Environmental and External Cause
Control system inadequate or defective Control system cannot be used when required Control system used incorrectly by operator Design functional deficiencies Inadequate installation of system Monitoring system faulty or inadequate	Normal environmental extremes Act of god and natural causes General accidental impact damage External energetic and toxic events External interference causing loosening <i>Force majeure</i> , sabotage, theft, hooliganism Effect of environmental and external cause on personnel

PLANT IN DANGEROUS STATE

The deviation and disturbances noted under this heading in Table 4 are expanded to identify specific cause within the HAZCHECK program. Other systems do much the same. Indeed the methodology of HAZOP is primarily directed at the identification of dangerous trends in operating conditions or a change in a planned discharge, and there is much value in having a terminology which readily focuses on possible disturbances. Study of the incident chain places a higher priority on identifying causes of overpressure and overtemperature than changes in flow. A breakdown of the usual causes of deviations is helpful as it reduces the reliance on the memory of the team or individual effecting the study.

TABLE 4 - Plant In Dangerous State

Dangerous Trend in Operating Conditions	Construction Defective or Deteriorated in Service
Underpressure, excessive vacuum	Loosening or disconnecting by personnel
Overpressure resulting from explosion	Loosening by vibration
Overpressure from connected pressure source	Corrosion, stress corrosion or erosion
Thermal expansion of process material	Distortion or aging due to chemical attack or thermal expansion
High temperature from direct source	Creep and fatigue
High temperature from increase in heating or decrease in cooling	Variations in loadings
High temperature from change in mixing	Water hammer or other change causing thermal stress, pressure waves or transient flows
High temperature from unexpected exothermic reaction at any location	Impact and changes due to excessive stress or force
Low temperature of wall, usually extremely cold	Out-of-tolerance faults: changes due to wear, friction, rubbing, thinning, weakening, etc.
Dangerous trend (see change in a planned discharge)	Deterioration due to external attack
	Defect or its propagation prior to failure
Change in a Planned Discharge or vent	Abnormal opening in equipment
Change of composition or concentration	Incorrect status of equipment valve or safety system
Change in phase, fraction of phase or additional phase	Failure of isolation device to air
Change of rate, velocity, direction or quantity of flow	Discharge of safety device
Change in size or other physical properties of process materials	Construction defective (leave open)
Change in a periodic or fugitive discharge or normal vent	Abnormal opening for entry or discharge
Change in dispersion of a discharge	

FURTHER DEVELOPMENT OF THE INCIDENT

Tables 5-7 follow the development of the incident. Clearly many of the activities relating to control of the situation by corrective or mitigating action take place at the same time. It is particularly important to stress the role of the operator in resolving many of the problems without the need for intervention by the emergency control systems. Maintenance is vital to preventing the release of material within the design mechanical limitations of equipment. At the same time the loosening of equipment by maintenance personnel is a major cause of the release of material.

Table 6 is useful as it emphasises the way in which release occurs given the plant in a dangerous state and the failure to control the situation. The loss of material may in itself be at a significant rate or it may accumulate. Explosion can initiate the release of material or cause secondary escalation. The spurious failure of a relief system can initiate the hazardous situation. However for purposes of analysis it is convenient to follow the sequence given here.

The frequency at which incidents might occur should be assessed together with the consequences of their occurrence. This can then be used to evaluate the hazard category of incidents.

TABLE 5 - Failure to Control the Situation

Emergency Control System Fail to Correct the Situation

Incorrect use of emergency control
Defect of emergency control system causes or increases danger
Emergency control systems inadequate or failed
Emergency control systems not provided, installed or available

Operators Fail to Control the Situation

Action of operators causes or increases hazards
Contingency action by operators fails to reduce trend
Incorrect discharge of the system through an available opening
Action of operators causes or increases hazard
Inadequate action by operators
Failure to take action by operators

Normal Control System Fails to Correct the Situation

Defect of control system causes or increases hazard
Control system inadequate or failed
Reading or indication is invalid
Incorrect use of control system
Control system not provided disabled or isolated

Maintenance Fails to Control the Situation

Malfunction causes or increases the hazard
Malfunction of maintenance causes or increases hazard
Inadequate action taken by maintenance
Failure to take action by maintenance

TABLE 6 - Unplanned Release of Material

Loss of Significant Process Material	Release of Material by Rupture or Discharge
Release detected but not isolated or attenuated before significant loss	Mechanical design limitations exceeded
Release not detected or reduced before significant	Rupture due to defective or deteriorated construction
	Loss through abnormal opening to atmosphere
	Change in a planned discharge, emergency discharge or vent

TABLE 7 - Escalating Events and Failure of Mitigation

Inadequate Post-accident Response	Inadequate Emergency Response
Inadequate post-accident action	Inadequate preparedness
Inadequate health control	Failure of information interface
	Inadequate protection environment, personnel and plant
Countermeasures Inadequate	Inadequate service arrangements
Inadequate segregation of people plant and external threats	Inadequate on-site response
Inadequate protection of plant personnel and environment	Inadequate response to leak
Inadequate countermeasures for vapour and gas emission	Failure to limit people on-site
Failure of secondary containment or avoiding vaporisation	Inadequate off-site response
Inadequate response of people	Inadequate segregation
Release fails to disperse	Escalation by Toxic Loss
Inadequate detection and activation of response	Further spread of release
Failure to attenuate loss	Further loss of toxic material due to explosion or evaporation
Inadequate detection and warnings	Failure to prevent reactions
	Failure of emergency relief treatment
	Failure to dilute material
	Release fails to disperse
Escalation by Explosion	Escalation by Fire
Secondary escalation by explosion	Further release of material following fire
Explosion of external vapour cloud	Ignition of fire previously extinguished
Explosion and BLEVE	Further spread of fire
Dust explosion	Failure to extinguish fire
Confined explosion prior to release	Flammables ignited on release
Physical or condensed-phase explosion	Failure of ignition source control
Runaway reaction of explosive force	Significant flammable mixture
Failure to avoid primary explosion	Fire prior to release
Electrical explosion	

HAZCHECK

HAZCHECK has been developed to provide an aid for the identification of factors affecting the development of an incident. HAZCHECK gives guidance; for example on contingency measures and emergency control systems. The structure of HAZCHECK follows that given in Figure 1 and Tables 2-7.

HAZCHECK runs on an IBM Compatible PC. The program contains extensive further notes on each topic so that, for example, overpressure from vaporisation can be subdivided into specific causes. In this way it is possible to use the expertise put into the programme as a means of generating causes for a specific plant incident. A window system is used to access the information. Thus the root cause 'Personnel inadequate in task' expands as follows:

Personal inadequate task Improper and inadvertant actions Inadequate quality and innate characteristics Inadequate task training and appraisal Inadequate safety training and rehearsal Task overload of personnel Inadequate operating environment

and 'Inadequate task training and appraisal' is then developed under the following headings

Inadequate task training and appraisal Inadequate experience in task or process Inadequate training Inadequate appraisal Inadequate opportunities for worker suggestions Disturbance caused by monitoring performance
--

HAZCHECK is a simple data base which may be used as a rough checklist. The process engineer can use it within any general strategy for implementing risk control. It is applied not solely at the design stage of plant but throughout the life of a plant, including its dismantling and disposal. Brief notes on applications to some recent incidents are noted in Table 8.

It would be helpful to be able to claim that a study of incidents justifies the breakdown and to give details of the contribution of each root cause. However this is frustrated by the lack of detail in incident reports. For example it is rare that reference is made to the adequacy of corrective and protective actions, and the identification of root cause is almost entirely ignored. Occasionally mention is made of lack of information or training and the capabilities of management may be criticized. But all too often a report might emphasise an immediate cause such as human error when inadequate human action due to specified root causes and failure of emergency control systems would be more appropriate. Indeed the root causes of the incident may not be defined even when blame is apportioned by the courts.

TABLE 8 - Some recent incidents

INCIDENT	IMMEDIATE CAUSE	FAILURE TO CONTROL THE SITUATION	MAIN ROOT CAUSES
Kings Cross 1987 Fire on escalator	Flammable material accumulated in escalator area	Failure to remove material. Absence of ignition control. Inadequate emergency response.	Change from design intent (lack of cleaning) Inadequate procedures (inspection, ignition) Inadequate emergency planning Inadequate fire protection Inadequate resources for maintenance workload Inadequate learning from previous incidents Inadequate safety objectives
Zeebrugge 6 March 1987 Capsize of ferry	Bow doors open on departure	No protection as doors open at critical speed/ sea conditions. Ship poorly trimmed	Inadequate procedures/communication Inadequate design of protection systems Inadequate training Change from design intent (doors open) Inadequate job supervision.
Camelford 8 July 1988 Pollution of public water supply	Aluminium sulphate unloaded into wrong tank	Failure to monitor water quality. Inadequate emergency response.	Inadequate procedures Inadequate emergency plan Inadequate task supervision Inadequate communication of requirements to driver.
Bhopal 3 Dec. 1985 Toxic gas release	Water incorrectly mixed with MIC and and reaction due to wrong routing or sabotage	Protection systems shutdown. Inadequate emergency response.	Inadequate design: pipework, spray size Inadequate procedures Inadequate emergency plan Inadequate maintenance of protective equipment Inadequate job supervision Possible sabotage Inadequate capabilities of management
BP Grange- mouth 13 March '87 Fire in Flare system	Loosening of flange when equipment not effectively isolated	Failure to cease work when leak noted. Failure of ignition control. Inadequate personal protection. Failure to shut-down downstream plants.	Inadequate procedures for maintenance and isolation Inadequate design (valve and layout) Inadequate job supervision Inadequate use of available information Inadequate training Inadequate communication at several levels Inadequate planning of task
Piper Alpha North Sea 6 July '88 Fire on Oil platform	Valve removed but replaced by cap that was not leak- proof. Start-up of pump after shift change	Explosion prevented emergency isolation and destroyed fire- wall. Incoming gas pipeline ruptured and gas burns as torch. Large pool fire on further escalation	Inadequate permit to work procedures Inadequate physical locking off/tagging of isolation valves. Inadequate communication on shift change Excessive inventory of flammables Inadequate location of emergency isolation valves Inadequate layout of rig Inadequate protection Inadequacy in fire and explosion of key equipment and emergency plan

GENERAL CONCLUSIONS

The analysis of incidents and the incident chain suggests that there is a need to apply four basic approaches within any structured programme of risk control. These are as follows:

- a) **Give attention to process design and inherent safety** with particular consideration of process route, equipment needed, inventory and operating conditions. All feasible reactions must be identified allowing for impurities being present.
- b) **Improve the engineering and operability of the system**, including all protective measures, with an emphasis on the use of the highest standards of engineering, plant realisation and maintenance, with effective monitoring which fully considers the role of the production and maintenance personnel, and having adequate safeguards to control any situation both on and off the site.
- c) **Control external threats and unplanned changes** by adopting a strategy that assumes a plant is under constant threat, particularly from human interference and the environment.
- d) **Implement total quality management in company and plant** to maintain constant vigilance to eliminate disturbances and faults. Monitor the frequency with which they occur, carry out regular safety audits and root-out problems at their inception.

HAZCHECK can help in all these tasks. It is being extended to permit of short-cut quantified risk analysis. This includes factors for the quality of the maintenance and the loss prevention programmes, the quality of engineering design and realisation and construction, the capabilities of the management and organisation, and the experience on-site for a specific process. Quantification of risk also helps in highlighting the immediate reduction of safety stemming from any removal or degradation of a clearly identifiable defence against incidents. Such degradation as arose at Bhopal can be analysed so as to suggest the likely frequency of a major incident as increasing from 10^{-4} per year to 10^{-1} per year or less.

The basic list also is being adapted to use a questioning approach for application in conjunction with conventional auditing methods. This is directed towards root cause analysis, the identification of performance indicators and the need for the two safeguard approach to protection against loss of control of the situation.

GENERAL REFERENCES

1. Crosby P B, Quality without Tears, McGrawhill, 1984.
2. Reeves A B, Davies J, Wells G L, Foster J, GOFA, Int.Conf. on Quality Management in the Nuclear Industry, IMechE, 17-18 Oct, London, 1990.
3. Wells G L, Safety in Process Plant Design, Godwin, 1979.




Figure 1 Development of an incident




Figure 2 Simplified representation of root causes






Figure 3 Suggested Relative Frequency of Events



KEY:

GOFA Goal Orientated Failure Analysis FTA Fault Tree Analysis
 FMEA Fault Mode and Effect Analysis QRA Quantified Risk Analysis
 HAZOP Hazard and Operability Studies TQC Total Quality Control

See General References for further information.

Figure 4 Activities and Analysis with Each Event