TECHNICAL REPORT

SYNOPSIS

My Technical report comprises of mainly the Concept Study Report and some of the Sample Calculations carried out by me:-

1) Concept Study Report for xxxx well flowlines Rationalisation Project along with Simulation input data and configuration

2) Operating Philosophy & Control Narrative for xxxx well flowlines Rationalisation Project

- 3) Safeguarding Narrative for xxxx Well flowlines Rationalisation Project
- 4) Calculations for PVV & Blow-off Hatch for Crude Storage Tanks
- 5) Calculations for sizing of Relief valve.

1. CONCEPT STUDY REPORT FOR XXXX WELL FLOWLINES RATIONALISATION PROJECT

I had started working on this project since its inception. The project was initiated mainly to avoid congestion of well flowlines in XXXX Production station corridor.

The oil producing wells are free-flowing and two-phase flow with no solids but some amount of water present in aqueous phase. So I had to simulate the model using PIPESIM 2006 Edition-2 software to calculate the pressure drop for the line size selected. The idea was to get together a cluster of wells based on the proximity to a Remote manifold OR MSV and run a single bulk header to the station. Fluid mechanics engineering design was considered for carrying out the hydraulics. Considering the number of bends and pipe fittings in addition to actual length, the equivalent length was calculated. Further, the limitation on continuous flow of liquid in pipe to avoid static charges build-up and erosion velocity of liquid was taken into consideration. In addition, a test header from each of the Remote manifold OR MSV for well testing mainly through a Multi-Phase flow meter (MPFM), was considered to measure the total flow.

My first priority was to build the simulation model for the existing wells. The production from the existing wells is routed to the 6" manifold at the station via individual 4" well flowlines. Configuring the flow of fluid through well downhole upto the choke valve was a challenging task. Relevant inputs were taken from the reservoir team. The ID and length of the well downhole upto the total depth was fed into the simulation model.

Further, the equivalent length of the flowlines downstream of the wing valve was calculated.

The simulation was carried out and verified.

Various Options were considered as stated in the report.

Finally, a cluster of seven new well flowlines routed to remote manifold was considered as the best option.

The MPFM (MultiPhase flow meter) has Venturi meter for liquid measurement, single Gamma source for GVF% measurement and Dual Gamma source for WC%.

For standard oil/gas calculations

Q_{VOS}= Q_{VO} * Shrinkage factor

where

 Q_{VOS} – Oil flow rate at actual condition, m3/d Q_{VO} – Oil flow rate at standard condition, Sm3/d Shrinkage factor – Crude Oil shrinkage coefficient

Qgs= Qg * P1* Tn/ Pn* T1/Z Factor+ Qvos* Solution GOR

where

Qgs – Gas flow rate, Standard, Sm3/day

Qg - Gas flow rate, actual, m3/day

P₁ - Absolute pressure, actual


Tn – Standard temperature (K)

Pn - Absolute pressure, standard

T₁ - Actual temperature (K)


Z Factor – Nature gas volume compressibility

Qvos- Oil flow rate, standard condition, Sm3/d




LOCATION OF WELLS AS PER CO-ORDINATES

Indes)PATE ... series\PAIE00001-00100 series\PAIE00058\1 proc



		ъ×
File Edit Setup View Tools Data Operations Artificial		E X
Choke	96810 CRAJ_17	A
N1 10000 CRA		
20	Choke - Choke_2	
<u>99</u>	Properties Advanced Choke Data (Optional) General	
Tubing_1		
Ecos	Sub-critical correlation Mechanistic	
	Critical Correlation Mechanistic	
Completion		
	NOTE: all correlations require hydrocarbon liquids at stock tank conditions except Mechanistic and API-148	
	Bean Size 56 mm 💌	
	Critical Pressure Ratio 0.53 🔽 Calculate	
	Tolerance 0.5 %	
· · · · · · · · · · · · · · · · · · ·	OK Cancel Help	
		+
LII AAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAAA		
🥑 start 🔰 🧕 🥙 😰 💿 🙆 Inbox - Micro		25 PM
	CHOKE VALVE DETAILS	



INPUTS FOR CALCULATIONS AND MODELLING

GRE details- Refer document No. 1561-DP-01

6"-120 bar(g)- ID-xxx mm Wall thickness – xxx mm Conductivity- 0.346 W/m deg K 4"-120 bar(g)- ID- xxxxx mm Wall thickness-7.061 mm.

Ground conductivity- 0.6400999 W/m/K Steel pipe conductivity- 50 W/m/K.

4 ½"-xxx-10000# - I.D-97.18 mm Thickness-17.12 mm 4'-xxxx- I.D-108.28 mm Thickness- 6.02 mm 6"-xxxxx I.D-161.19 mm Thickness-7.11 mm.

GRE Roughness factor- 0.001524

Equivalent length of 4" pipeline before choke valve – (actual length – 12.950 m) – 42 metres. Equivalent length of 4" pipeline after choke valve- (actual length- 39.500 m) – 51 metres.

Reservoir data considered

Pressure – xxx bar(g)-New wells xxx bar(g)-Old wells Temp.- 89 degC Well PI - Liquid Pi -xxx sm3/day/bar.

Tubing- Datum MD-0 Ambient temp- 5/60 degC SSSV MD-71 m ID-xx mm Perforations- xxxx m MD xxxx m TVD Tubing #1 – 0 xxxxx 99 Tubing#2 - xxxxx xxxx 75 Tubing#3 - xxxx xxxx 160

6 inch production header considered- 30 metres from Station manifold upto HP Separator 4 inch flowline from each well – 2 kms.

Pressure at XXXX manifold-86 bar (a). Criteria constraints for manifold- xxxx m3/day oil stn. Capacity GOR - xxxx.

APPROACH TO CALCULATIONS

For single well (4-inch flowline)

- 1) Equivalent length calculated for pipe length upstream of choke valve.
- 2) Equivalent length calculated for pipe length downstream of choke valve upto well -pad battery limit.
- 3) Flowline from well-pad battery limit upto Remote manifold

For Bulk header sizing from Remote manifold to Station manifold

The preliminary size considered was 6-inch identical to the Production header at the Station manifold.

Another challenge was the flow of oil from individual wells which is gradually decreasing. So a table was developed by me in Excel to evaluate the maximum oil flow from the wells to the station in particular year. The basis as provided by the reservoir team was that the new well will start producing 380 m³/day in the first month, 200 m³/day after 2 months and 150 m³/day after 3 months of commencement of production. The wells would be hooked up one at a time

Also, the production from existing wells will gradually decrease at an average rate of 35% from the flow rate for the previous year.

Since the flow was primarily two-phase flow, PIPESIM simulation was carried out for all the cases considered. I used API-14E equation for calculation of erosion velocity and cross-check with the output from the PIPESIM model. It was matching.

In order to avoid erosion damage and associated problems in two-phase flow systems, API RP14E recommends limiting the maximum production velocity to a value defined by the following empirical equation:

$V_{\bullet} = C/\sqrt{\rho}$

where

V_e = the maximum allowable erosional velocity in ft/sec

- p = the density of fluid in lb/cu ft at flowing conditions of temperature and pressure
- C = a constant generally known as the C factor, is in the range of 100 to 125

For a sand-free, two-phase flow situation, the C factor is limited to 100 for continuous flow and 125 for intermittent flow. The API RP14E recommends the use of a lower unspecified C factor for fluids containing sand. Based on the Pressure drop for Multiphase fluid flow as per Perry, Chapter 6 as reproduced below:-

MULTIPHASE FLOW

Multiphase flows, even when restricted to simple pipeline geometry, are in general quite complex, and several features may be identified which make them more complicated than single-phase flow. Flow pattern description is not merely an identification of laminar or turbulent flow. The relative quantities of the phases and the topology of the interfaces must be described. Because of phase density differences, vertical flow patterns are different from horizontal flow patterns, and horizontal flows are not generally axisymmetric. Even when phase equilibrium is achieved by good mixing in two-phase flow, the changing equilibrium state as pressure drops with distance, or as heat is added or lost, may require that interphase mass transfer, and changes in the relative amounts of the phases, be considered.

Wallis (One-dimensional Two-phase Flow, McGraw-Hill, New York, 1969) and Govier and Aziz present mass, momentum, mechanical energy, and total energy balance equations for two-phase flows. These equations are based on one-dimensional behavior for each phase. Such equations, for the most part, are used as a framework in which to interpret experimental data. Reliable prediction of multiphase flow behavior generally requires use of data or correlations. Two-fluid modeling, in which the full three-dimensional microscopic (partial differential) equations of motion are written for each phase, treating each as a continuum, occupying a volume fraction which is a continuous function of position, is a rapidly developing technique made possible by improved computational methods. For some relatively simple examples not requiring numerical computation, see Pearson (Chem. Engr. Sci., 49, 727–732 [1994]). Constitutive equations for two-fluid models are not yet sufficiently robust for accurate general-purpose two-phase flow computation, but may be quite good for particular classes of flows.

I therefore developed PIPESIM simulation model to calculate the pressure drop and the pressure to be maintained downstream of the individual well choke valve.

I counterchecked the simulation output with Flowline design calculations as per API-14E for two phase flowline calculations.

Attached herewith is a copy of the original report along with the results for your consideration.

XXXX WELL FLOWLINES RATIONALISATION

CONCEPT SELECTION REPORT

	:

TABLE OF CONTENTS

1		Management Summary	2
2		Background AND OBJECTIVES	3
3		SCOPE	3
4		EXISTING ARRANGEMENTS	4
	4.1 4.2	Existing Facilities Well Details	
	4.3	On Pad Well Piping and Flowline Details	.4
	4.4 4.5	Manifolds Well fluid Properties	
	4.	5.1 Solid Co-Production	.5
	4.	5.2 Water Production	
5		DESIGN PARAMETERS	-
	5.1	Flowline Routing	
		1.1 Flowlines length for calculations1.2 Design Basis	
	5.2	Civil Considerations	.6
	5.3	Capex of Individual Process systems/ Elements	.6
6		WELL HOOK-UP STRATEGY & Study Drivers	7
7		PLANNING BASIS	
	7.1	Key Assumptions	
8		CONCEPT IDENTIFICATION	8
	8.1 8.2	Key considerations Proposed Configuration for Well flowlines1	
9		CONCEPT SELECTION 1	2
	9.1	Comparison of Options1	
	9.2	Selection Criteria	
	9.3 9.4	Selected Concept1 Concept Definition and Optimisation1	
	9.	4.1 Line Capacity1	
10	D	SCOPE OF SELECTED OPTION 1	5
1	1	OVERALL ECONOMICS 1	6
1:	2	project cost estimate (CURRENT SCOPE)1	6
1:	3	RISK MANAGEMENT PLAN 1	7
14	4	PROJECT EXECUTION PLAN 1	8
1	5	FEED & DD SCOPE OF WORK 1	8
10	6	References1	9
	16.1	Acronyms and Abbreviations1	9
17	7	Appendices 2	20

1 MANAGEMENT SUMMARY

The report on Flowline Rationalisation study is contemplated to avoid criss crossing of the flowlines, optimally utilising the available slots at manifolds taking into account identified low producers that would be abandoned in future and minimise the extensive need of CRA manifold extensions which will restrict future field developments. It also aims at addressing the main issue of flowline routing to optimise the flowline lengths, reduce the demand on the space already occupied by flowlines, achieve more operational flexibility and minimise the hook up costs.

Use of Multi-Port Selector Valves or Remote Manifold assists a lot in achieving these objectives. This study covers all the wells upto 20XX (currently flowing wells as new wells).

'Remote manifold (7-slots) - 2 nos.' Option-2B is considered as the best option. The flowlines from the new wells would be routed to two remote manifolds located in field at strategic locations. The bulk header and test header from each of the Remote manifolds located in field would be hooked up to the manifold at XXXX. Depending on the constructability constraints, priority will be given to hook-up of new wells to Remote manifold, due to deferrment issues for the loss of oil production from the old wells, if the old well flowlines will be utilised as per Option-2A.

The well testing frequency is met by three MFM's which are proposed to be installed at XXXX station manifold to cater to the testing requirement of all producing wells upto 20XX.

The outcome of the flow line rationalisation would be applicable for the wells during the year 200X to 20XX.

The CAPEX for 'Two remote manifold – 7 slots' Option-2A is estimated as US XXXX as against 'Two-MSV's – 7-slots' which is estimated as US XXXXX mln. However, the remote manifold concept is selected as the preferred option due to the following:-

- i. MSV performance not proven for similar service (high pressure and high H_2S) in SSS or elsewhere
- ii. Limited vendor capability, only 1 vendor responded to our preliminary requests.
- iii. High risk to project, no fall back in case MSV's don't perform

2 BACKGROUND AND OBJECTIVES

Laying of independent flowlines in field and extension of the manifold within XXXX posed engineering complications and is not a preferred option. This approach would make the area congested and may impact road lay-out in the station. The concept of flowline rationalisation in the field is economically justified due to availability of Remote manifold suitable for XXXX fields. Flowline co-mingling of two old wells is perceived to be compromising WRM objectives and hence generally not supported.

The objective of the study is to carry out XXXX wells flowline rationalisation to avoid criss crossing of the flowlines, reduce the risks of working very close to high risk live flowlines, minimise the extensive need of CRA manifold extensions and reduce the possible restrictions for further development in future, if required.

This study would cover currently all the wells up-to 20XX (currently flowing wells as new wells). The main objectives of the study are as follows:-

- 1) Flowline routing to optimise the flowline lengths.
- 2) Reduce demand on the space already occupied by flowlines.
- 3) Achieve more operational flexibility for testing through MFM's and minimise on hook-up costs.
- 4) Meeting the well testing frequency by installing appropriate well test meters.
- 5) Optimal utilisation of the available slots at manifolds by taking into account low producers that would be abandoned in future.

Use of MSV's/Remote manifolds in place of on-plot manifold extension will achieve these objectives.

The outcome of this report on flowline rationalisation would be applicable for the wells during the year 200X and beyond.

3 SCOPE

The Scope of Work for the Concept Study is based on the following:-

- Gather all necessary information as required.
- Maximum capacity utilisation of the station.
- Due consideration of the production decline from the existing wells.
- Study the various options for installation of Multi-port Selector Valves / Remote manifolds and routing of individual well flowlines to MSV's /Remote manifolds.
- Routing of Bulk header and test header to manifold
- Investigate the capital and operating costs associated with the options.

4 EXISTING ARRANGEMENTS

4.1 Existing Facilities

4.2 Well Details

4.3 On Pad Well Piping and Flowline Details

The CITHP of the wells is xxx bar(a), and FTHP ranges from xxx bar(a) to xxx bar(a).

On-pad hook-up piping(4 $\frac{1}{2}$ ", 10000# API), ESD valve, choke valve, piping (4", 900#) from the choke valve, connected to a GRE (4",120 bar(g)) line to the existing manifold at inlet to Production Station.

The existing wells are hooked up to the manifold by individual well flowlines, shown in the sketch below:

4.4 <u>Manifolds</u>

Two manifolds, A-8XXXX and A-XXXX (extended manifold) exist at xxxx, providing 16 slots and no spare available slots. There are two existing MFMs. One new 4-slot manifold, A-81XX and one MFM will be added during the year 20XX.

4.5 <u>Well fluid Properties</u>

At the well-head, fluid temperature is in the range of xx deg C. The bubble point pressure of the fluids from these wells is typically xxx bar(g) at reservoir temperature of 90 deg C.

Component		% Mole
NITROGEN	N2	
CARBON DIOXIDE	CO2	
HYDROGEN SULFIDE	H2S	
METHANE	C1	
ETHANE	C2	
PROPANE	C3	
IBUTANE	C4	
PENTANE	C4	
IPENTANE	C5	
PENTANE	C5	
PSEUDO HEXANE	C6	
PSEUDO HEPTANE	C7	
PSEUDO OCTANE	C8	
PSEUDO NONANE	C9	
PSEUDO DECANE	C10	
PSEUDO UNDECANE	C11	
PSEUDO DODECANE	C12	
PSEUDO TRIDECANE	C13	
PSEUDO TETRADECANE	C14	
PSEUDO PENTADECANE	C15	
PSEUDO HEXADECANE	C16	
PSEUDO HEPTADECANE	C17	
PSEUDO OCTADECANE	C18	
PSEUDO NONADECANE	C19	
HEAVY END	C20+	
_CP3A*		
_CP3B*		
_CP3C*		
_CP3D*		
_CP3E*		
_CP3F*		
_CP3G*		
_CP3H*		
_CP3I*		
_CP3J*		

Following is a typical composition of the well fluid from XXXX listed in Table 4.5 below:

4.5.1 Solid Co-Production

Solid proppant is injected initially to assist in well drainage by maintaining well fracs. While most of the proppant is held in the formation, some of it is co-produced during well clean out through well test unit. There is no evidence of sand co-production so far from any of the xxxxx wells.

4.5.2 Water Production

The analysis in Table 4.5 above is on dry basis, i.e. without water. Water would be co-produced in small amount during initial phases which would be mostly recovered water (injected during well clean-out). This would cease within a few weeks or months of first production.

As the field matures, more and more wells would be drilled towards flank area, increasing the probability of water breakthrough and water co production on continuous basis. Should this occur, the impact would be more on the station side, requiring careful monitoring. No significant impact is expected on flow lines for the wells under reference.

5 DESIGN PARAMETERS

5.1 <u>Flowline Routing</u>

5.1.1 Flowlines length for calculations

The equivalent length of pipelines used for calculation of back-pressure on the choke valve outlet for various options are attached in Appendix-4. The hydraulic calculations using PIPESIM were carried out for the existing wells/ new wells flowlines.

5.1.2 Design Basis

Minimum inlet pressure at xxxx	86 bar (a)
GRE line Design Pressure	120 bar (g)
Temperature at well-head tap-off point	35-55 ⁰ C
Flowline Installation	Buried
Off-Plot flowline	GRE
On-Plot flowlines	

5.2 Civil Considerations

- Fencing/area requirements for MSV's and associated instrumentation required.
- Relocation of existing equipments for flowline corridor development.
- Canopy shade for instruments located in field.
- Any other Civil structure.

5.3 Capex of Individual Process systems/ Elements

The installed material cost, as estimated by ---, has been used for Cost Comparison between various Options considered for this study.

Material Description	Installed cost, k US\$/unit
Well pad hook-up	
7-slot Remote Manifold	
7-slot MSV	
GRE Flowlines, 4"- 120 bar(g) /km	
GRE Flowlines, 6"- 120 bar(g)/km	
Flare and vent stack, 30 m,4"	
Closed Drain Vessel, 10 m3	

6 WELL HOOK-UP STRATEGY & STUDY DRIVERS

The wells to be hooked up after year 200X require special attention in view of the following:

- 1) Congestion in field due to more Flowlines with longer lengths.
- 2) Higher hook up costs.
- 3) Construction Risk.
- 4) Bigger footprint area for Manifold in the XXXX.
- 5) Relocation of installed Equipment at XXXX.
- 6) Inadequate well testing

7 PLANNING BASIS

7.1 Key Assumptions

Assumptions and basic information are as follows:

• The new well will start producing 380 m³/day in the first month, 200 m³/day after 2 months and 150 m³/day after 3 months of commencement of production. The wells would be hooked up one at a time

8 CONCEPT IDENTIFICATION

8.1 Key considerations

Well Location

Since the new wells are located over a wide area, it is not possible to hook up all new wells with new MSV or new manifolds without extensive criss-crossing and excessive use of materials.

• Manifold Slots Availability at xxxx

14 new slots are required to hook up 14 new wells at xxxx between year 200X to 20XX. The existing available 20 slots at manifold are part of one 10 slot manifold, another 6 slot manifold and one new four slot manifold (being executed). These are considered as occupied by 22 wells (upto year 200X).

• Flowline Capacity

The maximum fluid handling capacity of the flow line capacity would be based on:

- Available pressure difference
- Maximum permissible fluid velocity
- Erosion velocity

The pressure at well pad is regulated by choke valve (upstream or downstream). The minimum pressure upstream of choke valve is considered as xx bar(g) and downstream of choke valve may vary between xx bar(g) to xx bar(g).

The pressure at manifold inlet is determined by HP separator operating pressure, set at xx bar(g). The maximum manifold inlet pressure is considered as xx bar(g) to accommodate flow through MFM during well testing.

Thus the line capacity would be determined by a maximum permissible differential pressure of xx bar(g).

• Production Gathering

Production from each well has so far been routed to station through individual 4" line. However, several flowlines can be joined together and flow as single line to xxxx to achieve study drivers listed in section 6.0 above. The flowlines can be grouped using conventional type remote manifold or Multiport Selector Valves (Reference:-Literature from Framo). A combination of MSV's and manifold is also considered to examine, if it leads to more savings.

MSV	Conventional	manifold
	Remote Manifold	At XXXX
	(In Field)	
Seven wells can be hooked up to single MSV	Any no. of wells can be routed by designing required slots	Extension of existing manifold may not be possible. Further expansion constrained by space & pipelines. Requires relocation of existing equipment, microwave tower.
Compact dimensions- by routing of single production header and test header to manifold avoiding congestion of flowlines	Larger dimensions - Individual flow lines from each well thereby congestion and associated construction problems	Larger dimensions - Individual flow lines from each well thereby congestion and associated construction problems
Less number of valves	More number of valves	More number of valves
Lower installed cost	Higher costs	Higher costs
Instrument assisted remote operation from DCS	Manual operation (located far away from station thereby travel involved)	Manual operation, no travel involved
Single vendor	Many fabricators	Many fabricators
New draining and venting systems required in field.	New draining and venting systems required in field	New draining and venting systems not required
Maintenance issues and well testing needs to be looked into to avoid deferment in case of failure.	No known maintenance issues.	No maintenance issues.
No prior experience in operation of MSVs	Operator experienced to handle manifold operation	Operator experienced to handle manifold operation

• Comparison of MSV's with Manifold

• Location of MSVs or Remote Manifold

Proximity to wells and routing of the flowlines is the key consideration in fixing the location of the MSVs or Remote Manifolds.

• Foot Print Area of Flowlines at XXXX Entrance

To lay 14 new GRE lines, only 5.7 metres of space is available at entrance corridor against minimum 20 metres additional space required.

• Well Testing and MFM location

A total of three MFM's will be required for all the wells (new and existing). The two existing MFM's shall be replaced by new type and one new MFM will be installed. The MFM's for well testing can be installed in field or at xxxx.

MFM's are delicate instrument and require routine operator attention and protection from intrusion. Supervising the instruments like MFM's at remote locations is not convenient. In the event of non-availability of a particular MFM, the piping flexibility can be provided inside XXXX.

In most likelihood, one of the existing GRE lines would be used as test header.

Above advantages far outweigh the cost of laying a new test header from MFM to Station. Therefore, MFM installation at XXXX is preferred.

Refer Appendix-5, justifying the need of three MFMS, along with well co-ordinates. It is to be noted that the co-ordinates of new wells are tentative and may vary by \pm 500 m.

8.2 <u>Proposed Configuration for Well flowlines</u>

Option	Concept
1	INDIVIDUAL FLOWLINES
2A	CONVENTIONAL REMOTE MANIFOLD (existing wells hook-up)
2B	CONVENTIONAL REMOTE MANIFOLD (new wells hook-up)
3	TWO MSV's, 7 Slots
4	FIVE MSV's, 7 Slots

Four options have been considered to hook up new wells:-

Option 1 – 'Individual Flowlines'

Continue to route the individual flowlines from the (new) wellheads upto the manifold in xxxx. This will lead to congestion in well flowline corridor and relocation of equipment / Radio Antenna post in the corridor.

Option 2A - 'Conventional Remote Manifold' -old/existing wells hook-up

This concept considers co-mingling of well flowlines and well testing at xxxx. It does not consider further drilling of new wells beyond 20XX. The table below shows the arrangement of Remote manifold to accommodate all the wells up-to 20XX

	Up-to 200X		200X-20XX		
Well	No. of		No. of		
Routing to	wells	Flow Lines	Wells	Flow Lines	
To Remote Manifold	15	New Flow Lines	1	New Flow Line	
XXXX Manifold	6	use dedicated, existing flowline	14	12 wells use Old flowlines released by other wells 2 wells use new flow lines	
Total	21		15		

One new 6"-120 bar(g) bulk header and one 4"- 120 bar(g) test header would have to be provided from each of the remote manifold. The arrangement for venting and evacuation on remote site using a vacuum truck are considered necessary. Please refer Typical PEFS for Remote manifold with venting/drain arrangement attached in Appendix-3.

Option 2B – 'Conventional Remote Manifold' New wells hook-up

This concept considers routing of new well flowlines to Conventional remote manifold. It does not consider further drilling of new wells beyond

One new 6"-120 bar(g) bulk header and one 4"- 120 bar(g) test header would have to be provided from each of the remote manifold. The arrangement for venting and evacuation on remote site using a vacuum truck are considered necessary. Please refer Typical PEFS for Remote manifold with venting/drain arrangement attached in Appendix-3.

Option 3 – 'Two MSVs'

This Option is similar to option 2A above, except that the remote manifold is replaced by MSV.

Option 4 – 'Five MSVs'

This concept considers possibility of drilling of more wells beyond 201X nd therefore requires provision to accommodate new wells which are not yet firmed up. This concept would avoid hook up of more wells without having to install new remote manifold or MSV's. The table below shows the arrangement of MSVs to accommodate all the wells up-to 20XX

	Up-to 200X			200X-20XX
Well Routing to	No. of wells	Flow Lines	No. of Wells	Flow Lines
To MSV	16	New Flow Lines	10	New Flow Lines
xxxxx Manifold	5	use dedicated, existing flowline	5	5 wells use Old flowlines released by other wells
Total	21		15	

9 CONCEPT SELECTION

9.1 Comparison of Options

The primary difference between Option 1/2 and Option 3/4 is segregation of the old/new well flowlines to MSV's.

PARAMETERS	OPTION-1	OPTION-2A*	OPTION-3	OPTION-4
	INDIVIDUAL FLOWLINES	REMOTE MANIFOLD	2-MSVs	5-MSVs
New GRE flowlines				
No. of Joints in field (New-Old GRE flowlines)	None	30	30	20
No. of new GRE flowlines crossing old GRE flowlines	456	128	128	117
No. of locations for above crossings	35	24	24	20
No. of Road crossings for new GRE flowlines	84	49	49	112
Station corridor expansion, metres	20	6	6	6.6
Equipments to be relocated	1)Radio Antenna Post 2)Amine Storage Tank T-X	NIL	NIL	Radio Antenna Post

* Option-2B comprises of hook-up of flowlines from new wells to Remote Manifold.

** The tank is located in plant area and relocation is not easy, as it would impact other equipment and piping, requiring further study and investigations.

9.2 Selection Criteria

The criteria used to select the optimum concept are as follows:

- Minimise subsurface risk.
- Technically robust.
- Minimise initial Capex exposure
- Economically robust
- Comply with corporate HSE policy.

9.3 <u>Selected Concept</u>

Option-2B with "TWO REMOTE MANIFOLD's- 7 slots" is the most suitable option due to the following:-

- MSV performance not proven for similar service (high pressure and high H₂S) in XXX elsewhere
- The number of Road crossings & "criss crossing" between existing and new flowlines is less than for Option 1 and Option 4.
- The station corridor (width) for incoming flowlines is less than in Option-1.
- No deferment issues due to loss of oil production is envisaged.

9.4 Concept Definition and Optimisation

9.4.1 Line Capacity

Qualifications:

GRE Line is from MSV to manifold at XXXX/CRA-6" Manifold piping/CRA-4" Well-pad piping. Ambient Temperature- 60 deg C Average Flowing Fluid Temperature -55 Deg C The maximum flow rates for well fluids based on liquid velocity criteria are as follows:-

	Maximum Permitted Liquid	Permitted	At Liquid Velocity of 4.0 m/s (As predicted by PIPESIM)				Flow Pattern	
e ji ji e Veloc		Velocity (Ref	At Op	At Operating Conditions		At Standard Conditions		
Flov Mat	S	GRE Vendor)	Superficial Liquid Velocity	Erosion Velocity	Fluid Mean Velocity (Oil+gas)	Liquid	Associated Gas	
		** m/s	m/s	m/s	m/s	sm3/d	sm3/d	
GRE	6"							
GRE	4"							
CRA	6"							
CRA	4"							

Considering the erosion velocity, as predicted by PIPESIM, as the limit for fluid mean velocity considering two-phase flow, the maximum flow rates at Standard conditions for well fluid (Stock Tank Conditions) are as follows:

	Size	At Fluid mean Velocity near to Erosion Velocity (As predicted by Pipesim)				Flow Pattern	
Flowline Material		At Operating Conditions		At Standard Conditions			
Flov Mat	Si	Superficial Liquid Velocity	Erosion Velocity	Fluid Mean Velocity (Oil+gas)	Liquid	Associated Gas	
		m/s	* m/s	m/s	sm3/d	sm3/d	
GRE	6"						
GRE	4"						
CRA	6"						
CRA	4"						

10 SCOPE OF SELECTED OPTION

The two Remote manifold's will be located based on the proximity to new wells based on the coordinates as provided by the Reservoir Engineering group and new flowlines will be routed to individual Remote Manifold's. One 6" bulk header and one 4" Test header will be routed from each of the two remote manifold's located in the field to the manifold located at xxxx. Venting and draining facilities are to be provided adjacent to the Remote manifold installation for maintenance purposes.

11 OVERALL ECONOMICS

The cost estimates (k US\$) for each of the options are summarised in the table below: These are based on the estimates received from XXX.

			Opti	ions	
Description	Capex	1	2A	3	4
Well pad hook-up, for 15 wells	on Pad CRA, k US\$				
7-slot 'Remote Manifold for 14 wells/ MSVs	Two Nos., k US\$				
GRE Flowlines	4" & 6"- 120 bar(g), k US\$				
TOTAL	k US\$				

Note:- The cost for relocation of equipments in Option-1 and Option-4 is not included in total estimate.

The overall cost in Option 4 will be still more due to routing of new and old well flowlines to MSV's and number of road crossings.

12 PROJECT COST ESTIMATE (CURRENT SCOPE)

Out of the total scope of rationalisation project (Option-2B) including well hook-up scope till 20XX, current scope of the project comprises of installation of remote manifold along with drain/vent facilities (2 sets) and the 6" / 4" bulk/test headers from each of the remote manifold to station. Cost estimate for the current scope as worked out by XX is as below :-

Description of facilities	CAPEX cost, kUS\$	Cost allocated in PEEP, kUS\$
7-slot manifold & associated drain / vent facilities (2 sets)		
6" & 4" GRE headers (2 nos. per manifold)		
TOTAL		

13 RISK MANAGEMENT PLAN

No.	Impact / Likelihood	Risks / Uncertainity	Consequence	Mitigation
1	M/M	Leaks in flanges of Remote manifolds	more maintenance, shutdown, deferment	Proper preventive maintenance and good constructability. Each of the well flowlines to manifold can be isolated to avoid disruption of total flow.
2	M/M	Cost escalation	Impact on Project Cost and schedule	Current steel price + 15- 30% future mark-up considered for each item
3	M/M	Poor well field performance	No need to install Remote manifolds	Sub-surface uncertainities minimised due to extensive work

14 PROJECT EXECUTION PLAN

Contracting, Procurement & Construction Strategy

Project schedule

In order to optimise overall project schedule, FEED and DD have been shown as separate activities in the schedule. However, respective FEED & DD activities shall proceed seamlessly without waiting for a formal FEED closure. Successful FEED completion is a key success factor for the project and hence utmost care must be taken to ensure it's competition in totality within schedule duration.

This schedule will be developed further and optimised during the FEED stage of the project as the scope of work is firmed up, resources are allocated to the project, and commitments made. Specific schedules developed by the individual vendors and contractors will be summarised based on their CTR catalogues and interfaced with the overall project schedule.

It is apparent from the schedule that no new wells can be hooked up thru' the remote manifold facilities till 2000. Therefore, first 2 wells of 20XX may be hooked up to the free slots of new station manifold being installed under another project. Schedule for hook-up of further wells shall be developed based on completion of rationalisation project scope.

Design Integrity, Safety & HSE Reviews

Design integrity shall be managed by compliance with the Project Engineering Code of Practice, and through the application of the relevant design guidelines, procedures and specifications. HAZOP, IPF and Design Reviews will be conducted throughout the FEED and DD stages of this project.

The project will implement a process of Hazard and Effects Management (HEMP) throughout the design, construction and commissioning phases consistent with PDO's corporate policy. The necessary HEMP reviews studies and audits shall be integrated into the overall planning to ensure that these requirements are met.

15 FEED & DD SCOPE OF WORK

Refer to Appendix 6 for FEED SOW

16 REFERENCES

16.1 Acronyms and Abbreviations

AG BFD BG BS&W CA CITHP CP CS CSR DCS DD DEP ESDV ESD FBE FDP FED FTHP GRE HAZOP HIC MAOP MAIP MF MFM MOC MOL MSV NB PE	Above Ground Basis for Design Below Ground Basic Sediment & Water Corrosion Allowance Closed In Tubing Head Pressure Cathodic protection Carbon Steel Concept Selection Report Distributed Control System Detailed Design Design and Engineering Practice Emergency Shutdown Valve Emergency Shutdown Valve Emergency shutdown Fusion Bonded Epoxy Field Development Plan Front End Design Flowing Tubing Head Pressure Glass Reinforced Epoxy Hazard and Operability (Study) Hydrogen Induced Cracking Maximum Allowable Operating Pressure Maximum Allowable Incidental Pressure Manifold Multi-Phase Flow Meter Material of Construction Main Oil Line Multi-Selector Valve Nominal Bore Polyethylene
NB	Nominal Bore
PFS PEEP	Process Flow Scheme Petroleum Economic Evaluation Programme
PEFS	Process Engineering Flow Scheme
PL	Pipeline
PLC	Programmable Logic Controller
RTU	Remote Telemetry Unit
RV	Relief Valve
SCADA	System Control and Data Acquisition
SSC	Sulphide Stress Cracking
TSS	Total suspended solids

17 APPENDICES

Appendix 1 -	Correspondences(Not attached)
Appendix 2 -	Cost Estimates (Not attached)
Appendix 3 -	Drawings
Appendix 4 -	Inputs to Option for Concept Study (Not attached-included
	in synopsis)
Appendix 5 -	Well hook-up plan and MFM availability
Appendix 6 -	FEED & DD Scope of work (Not attached)

Appendix 3 – Drawings

Sketch-001: Well flowlines from old wells hooked up to manifold
Sketch-002: Well flow lines from New wells hooked up to manifold
Sketch-003: Well flowlines from old/new wells hooked up to manifold (Option-1) & Plot Plan
Sketch-004: Proposed hook up of old/new wells to Remote manifold and new well flowlines to be hooked up to old well flowlines and routed to manifold (Option-2A) & Plot Plan
Sketch-005: Proposed hook up of old/new wells to MSV's and new well flowlines to be hooked up to old well flowlines and routed to manifold (Option-3) & Plot Plan
Sketch-006: Proposed hook-up of old/new wells to MSV's (Option-4) & Plot Plan

Typical Remote Manifold PEFS and Accessories Schematic diagram for selected concept – Option 2B

Appendix 4 – Inputs to Options for Concept Study

- A) Well Production flowrates
- B) Well Data for Calculations and PIPESIM modelling
 C) Well Production Projected Profile
 D) Additional Flowline lengths for each Option
 E) Flowline Construction criteria

- F) Typical Well Pad hook-up PEFS

Appendix 5 – Well Hook-up and MFM availability

OPERATING PHILOSOPHY & PROCESS CONTROL NARRATIVE

TABLE OF CONTENTS

1.0.	OBJECTIVE
2.0.	INTRODUCTION
3.0.	OPERATING PHILOSOPHY & PROCESS CONTROL NARRATIVE
3.1.	WELLS/ REMOTE MANIFOLD FACILITIES / XXXX MANIFOLD OPERATION3
3.2.	WELL CAPACITY CONTROL / RMF PRODUCTION HEADER / TEST HEADER ROUTING TO XXXX
3.3.	WELL TESTING AT XXXX4
ATTACHN	IENT – 1

PROCESS FLOW SCHEME

1.0. OBJECTIVE

2.0. INTRODUCTION

3.0. OPERATING PHILOSOPHY & PROCESS CONTROL NARRATIVE

3.1. Wells/ Remote Manifold facilities / XXXX manifold operation

XXXX Wells

The wells are provided with a Surface Safety Valve (SSV) and a Surface Controlled Subsurface Safety Valve (SSSV). These valves are operated by a hydraulic panel located at the well head. The wells can be operated from the well head through well hydraulic panel thereby ensuring the safeguarding of the flow line. However, wells can also be closed from the XXXX control room.

The well head alarm and safeguarding signals for the new wells will be hooked up with XXXX control room DCS via FOC through Remote manifold IPS. The well operating parameters are transmitted to XXXX control room.

Remote manifold

There will be two remote manifolds located at two separate locations for gathering the crude from different wells. A typical remote manifold facility is as described below.

The 7-slot remote manifold is designed to facilitate hook-up of flowlines from 7 new wells to route the well fluid flow to the XXXX manifold.

The manifold will comprise the following:-

- 1) 6-inch Production header hooked upto bulk header.
- 2) 4-inch test header hooked upto test header.

All operations at the remote manifold locations are manual. The testing of wells is also manual operation. The testing is done manually by diverting (opening appropriate valves) the flow from the well required to be tested to the 4" test header.

Pressure indications are provided on Bulk and test headers, which provide pressure indications at Remote manifold location as well as at XXXX control room.

For venting of hydrocarbon from the new facilities (Remote manifolds) during routine maintenance or shutdown, no drain and vent facilities have been provided. If well flowlines and manifold are to be drained, this will be carried out by flushing via the 4-inch test header to the station manifold.

All operations at XXXX manifold are manual.

3.2. Well Capacity Control / RMF production header / test header routing to XXXX

No separate control systems are provided at Remote manifold location for control of pressure/flow from the individual wells. The wells are provided with the automated choke valves of Mokveld make for regulating the well head pressure.

The choke valve on the well flow line regulates the well head pressure, hence the downhole flowing pressure is regulated/maintained above bubble point pressure. The set points of the pressure controller will be set from XXXX control room through FOC. Set points can also be given locally through a suitable over-ride.

3.3. Well Testing at XXXX

ATTACHMENT – 1

PROCESS FLOW SCHEME

SAFEGUARDING NARRATIVE

TABLE OF CONTENTS

1.0	OBJECTIVE	.3
2.0		.3
3.0	SAFEGUARDING NARRATIVE	.3
3.1	Flowline and Remote Manifold System	.3
3.2	Manifold Skid at XXXX / MFM unit	.3
3.3	Fire and H ₂ S gas detection / Shutdown	.3
3.4	Process Shutdown (PSD) and Emergency Shutdown (ESD)	.4
ATTACHN	1ENT – 1 PSFS	

1.0 OBJECTIVE

2.0 INTRODUCTION

3.0 SAFEGUARDING NARRATIVE

The flowlines and manifolds are protected against overpressure through an Instrumented Protective System (IPS) located at the well pad. Each well is provided with a Surface Safety Valve (SSV) and Surface Controlled Subsurface Safety Valve (SSSV). These valves are operated by a hydraulic panel located at the well head. The SSV and SSSV are used for well tripping purpose during the shutdown. At the well head area, three panels are provided. These are well hydraulic panel, Field PAC panel and Instrument Protective System (IPS) panel. Well hydraulic panel is used for the open/close operations of SSV, SSSV and choke valve. Field PAC Panel is used for choke valve control. IPS panel is used for well and flowline safeguarding purpose.

Also an ESD valve is provided on each of the well flowline at the upstream of the choke valve for safeguarding purpose utilising the hydraulic shutdown system by IPS.

The pipeline overpressure protection is classified based on SIL-3 function which closes the SSV valve (in addition to choke valve and ESD valve) on flowline pressure high-high and closes the choke valve and ESD valve on flowline pressure high (2 transmitters- 1002 function).

3.1 Flowline and Remote Manifold System

CITHP of the wells is xxx bar(g). The wellhead portion up to choke valve (including choke valve) is fully rated (10000# API) for this CITHP value.

Remote manifold safeguarding logic blocks will be located in IPS at Remote manifold sites, respectively. This will be linked to XXXX DCS via FOC for transmitting Remote ESD signals from XXXX and Pressure indication / trip status signals to XXXX.

The relief valve option is not advisable in this system as the relief valve discharge should go to closed system which is not available and lead to a large sized system, if executed. Also the fluid contains high H_2S (i.e. approximately 1.5 mole %) and it is not feasible to install such type of system at each well head. Therefore, it is decided to provide Instrumented Protective System for safeguarding of the 120 bar (g) GRP flowline and CRA piping / manifold system.

The basis of the trip setting is to protect the pipeline from rupture due to overpressure.

3.2 Manifold Skid at XXXX / MFM unit

The Bulk header and test header from each of the Remote manifolds will be connected to new interface piping skid provided at the XXXX manifold located at XXXX.

3.3 Fire and H₂S gas detection / Shutdown

ATTACHMENT – 1

PSFS

To determine the maximum flow for "G" orifice for conventional carbon steel Relief valve with set-pressure of 1500 kPa(g)

REFERENCES

- 1 API RP-520, Seventh Edition, January 2000
- 2 API 526, Fifth Edition, June 2002

DESIGN INPUT DATA :

Rekief valve set-pressure =1500
kPagRelief valve over-pressure10
%Relief valve will discharge into the atmospheric drain pipe.

Flowing Temperature considered = 5° °C or 278.15 °K Relief valve flow considered = 960 m3/day

For an estimate, API-520 equation for liquid relief will be used to determine the size of the RV.

Calculation of the relief area

Calculating the orifice area required to pass the liquid

The following illustrates the calculation of required orifice area for capacity certified valves at 10% over pressure as given in API-520.

US Customary Units

$$A = \frac{Q}{38K_{d}K_{w}K_{c}K_{v}}\sqrt{\frac{G}{p_{1}-p_{2}}}$$
(3.9)

SI Units

$$A = \frac{11.78 \times Q}{K_d K_w K_c K_v} \sqrt{\frac{G}{p_1 - p_2}}$$
(3.9)

where

- A = required effective discharge area, in.² (mm²).
- Q = flow rate, U.S. gpm (liters/min).
- K_d = rated coefficient of discharge that should be obtained from the valve manufacturer. For a preliminary sizing, an effective discharge coefficient can be used as follows:
 - = 0.65 when a pressure relief valve is installed with or without a rupture disk in combination,
 - = 0.62 when a pressure relief valve is not installed and sizing is for a rupture disk in accordance with 3.11.1.2.
- K_w = correction factor due to back pressure. If the back pressure is atmospheric, use a value for K_w of 1.0. Balanced bellows valves in back pressure service will require the correction factor determined from Figure 31. Conventional and pilot operated valves require no special correction. See 3.3.

- K_c = combination correction factor for installations with a rupture disk upstream of the pressure relief valve (see 3.11.2),
 - = 1.0 when a rupture disk is not installed,
 - = 0.9 when a rupture disk is installed in combination with a pressure relief valve and the combination does not have a published value.
- K_v = correction factor due to viscosity as determined from Figure 36 or from the following equation:

$$= \left(0.9935 + \frac{2.878}{R^{0.5}} + \frac{342.75}{R^{1.5}}\right)^{-1.0}$$

- G = specific gravity of the liquid at the flowing temperature referred to water at standard conditions.
- p_1 = upstream relieving pressure, psig (kPag). This is the set pressure plus allowable overpressure.
- p2 = back pressure, psig (kPag).
- R = Reynold's Number.

Substituting the values,

Kd =0.65 (Relief valve is installed)Kw =1 (Conventional valve)Kc =1 (Rupture disk not installed)For preliminary orifice sizing,Kv =G =0.908 (Sp. Gr. Of crude oil)r =908 kg/m3 (Density of crude oil)p1 =Relieving Pressure = (1 + % Over-pressure/100) x the safety valve set-pressure=(1 + 10/100) * 15001650 kPagp2 =150 kPag (Max. expected back-pressure as RV discharges to atmosphere)Substituting the values,Required orifice area Ari =11.78 * 666.67 *
$$0.867^{0.5}/[0.65 * 1 * 1 * 1 * (1650 - 150)^{0.5}]$$
(Initial guess)Ari =297.26 mm²0.461 in²The selected available area for carbon steel conventional valve Asi is0.503 in²3.25E-04 m²

ı

50.23 cp μ=

Reynold Number R = $Q x (18800 x G) / [\mu x (A)^{0.5}]$

Substituting the values,

R =	666.67 x 18800 x 0.908 / (50.23 x 324.52 ^{0.5})
	12576.84

Substituting the value of R to determine Kv,

$$Kv = \frac{1/(0.9935 + 2.878/R^{0.5} + 342.75/R^{1.5})}{0.980964}$$

Required Orifice Area Ar = Ari/Kv =297.26 / 0.980964 303.03 mm^2

0.470 in²

The selected available area for carbon steel conver	0.503 in ²		
(based on Table 1 in API-526)			324.52 mm^2
			$3.25E-04 m^2$
Actual flow expected through relief valve =	O As/Ar		
Actual now expected through tener valve –	=40 * 0.503	/ 0.470	
	42.84	m3/hr	
	1028.07	m3/day	
Based on API-526, orifice for conventional safety	valve is	1 1/2" G 3"	
with safety valve inlet flange rating of	150#	and	
safety valve outlet flange rating of	150#		

Table 1—Standard Effective Orifice Areas and Letter Designations

Designation	Effective Orifice Area (square inches)
D	0.110
Е	0.196
F	0.307
G	0.503
Н	0.785
Ĵ	1.287
K	1.838
L	2.853
М	3.60
N	4.34
Р	6.38
Q R	11.05
R	16.0
т	26.0

DBNO						ppor	~E00			^		ΩÞ								ידאם	=			
Sizing of PVV & Blow Hatch for Settling tank (T-XXXX) & Reclaimed fluid tank (T-XXXX) for XXXX production stats Following cases are to be considered: 1 Normal outpression 2 Failure of blanket gas control valv. 4 Fire case 5 Instrument & power failure case 5 Instrument & power failure case 6 ASSUMPTIONS 1 For calculation purpose it is assumed that crude transfer pump & water + solid drain are not carried 1 simulaneously. 1 For Colculation purpose it is assumed that crude transfer pump & water + solid drain are not carried 1 simulaneously. 1 For Colculation purpose it is assumed that crude transfer pump & water + solid drain are not carried 1 simulaneously. 1 For Colculation purpose it is assumed that crude transfer pump & water + solid of rain case or PCV failure case 1 For Colculation purpose it is assumed that crude transfer pump & water + solid of rain case or PCV failure case 1 For PCV failure case indeleted 1 For PCV failure case line length of Blanket gas line from Battery limit to Settling / Reclaimed fluid tank assumed to be 250 meter & the same to be confirmed during detail engineerin 5 EVALUATION OF DESIGN CASES 2 Diameter 9 Hearth is 2.0 Persign (PAR) (p) / (-) 64 Kga (g), A per API (20) (clause 9.2.2) & API (20) the accumulation 1 ESF (-) 64 Kga (g) / (-) 0.56 KPa (g). 5 Et pressure of Design CASES 1 Diameter 9 Hearth is 2.0 Persign (PAR) (g) / (-) 0.56 KPa (g). 5 Et pressure of Divor off Hatch 1 22 m (rait 10 % accumulation) in the tank will be 1.81 Kpa(g) 1 Therefore volume of tail 122 m (rait 0 % accumulation) in the tank will be 1.81 Kpa(g) 1 Therefore volume of tail 122 m (rait 0 % accumulation) in the tank will be 1.81 Kpa(g) 1 Therefore volume of tail 122 m (rait 0 % accumulation) in the tank will be 1.81 Kpa(g) 1 Therefore and interesting and the cascianted fluid tank. 1 Normal interesting target is accumulated in the formed target accumulation of clause 1 (-) Normal interesting target (-) (-) 0.56 KPa (g). 1 Normal interesting target is the tex (-) (-) 0.56 K	IOB NO			DEPART		PRU	JE99			_ /	UTH								- '	DATE				
Sizing of PVV & Blow Hatch for Settling tank (T-XXXX) & Reclaimed fluid tank (T-XXXX) for XXXX production stats Following cases are to be considered: 1 Normal outpression 2 Failure of blanket gas control valv. 4 Fire case 5 Instrument & power failure case 5 Instrument & power failure case 6 ASSUMPTIONS 1 For calculation purpose it is assumed that crude transfer pump & water + solid drain are not carried 1 simulaneously. 1 For Colculation purpose it is assumed that crude transfer pump & water + solid drain are not carried 1 simulaneously. 1 For Colculation purpose it is assumed that crude transfer pump & water + solid drain are not carried 1 simulaneously. 1 For Colculation purpose it is assumed that crude transfer pump & water + solid of rain case or PCV failure case 1 For Colculation purpose it is assumed that crude transfer pump & water + solid of rain case or PCV failure case 1 For PCV failure case indeleted 1 For PCV failure case line length of Blanket gas line from Battery limit to Settling / Reclaimed fluid tank assumed to be 250 meter & the same to be confirmed during detail engineerin 5 EVALUATION OF DESIGN CASES 2 Diameter 9 Hearth is 2.0 Persign (PAR) (p) / (-) 64 Kga (g), A per API (20) (clause 9.2.2) & API (20) the accumulation 1 ESF (-) 64 Kga (g) / (-) 0.56 KPa (g). 5 Et pressure of Design CASES 1 Diameter 9 Hearth is 2.0 Persign (PAR) (g) / (-) 0.56 KPa (g). 5 Et pressure of Divor off Hatch 1 22 m (rait 10 % accumulation) in the tank will be 1.81 Kpa(g) 1 Therefore volume of tail 122 m (rait 0 % accumulation) in the tank will be 1.81 Kpa(g) 1 Therefore volume of tail 122 m (rait 0 % accumulation) in the tank will be 1.81 Kpa(g) 1 Therefore volume of tail 122 m (rait 0 % accumulation) in the tank will be 1.81 Kpa(g) 1 Therefore and interesting and the cascianted fluid tank. 1 Normal interesting target is accumulated in the formed target accumulation of clause 1 (-) Normal interesting target (-) (-) 0.56 KPa (g). 1 Normal interesting target is the tex (-) (-) 0.56 K																								
Sizing of PVV & Blow Hatch for Settling tank (T-XXXX) & Reclaimed fluid tank (T-XXXX) for XXXX production stats Following cases are to be considered: 1 Normal outpression 2 Failure of blanket gas control valv. 4 Fire case 5 Instrument & power failure case 5 Instrument & power failure case 6 ASSUMPTIONS 1 For calculation purpose it is assumed that crude transfer pump & water + solid drain are not carried 1 simulaneously. 1 For Colculation purpose it is assumed that crude transfer pump & water + solid drain are not carried 1 simulaneously. 1 For Colculation purpose it is assumed that crude transfer pump & water + solid drain are not carried 1 simulaneously. 1 For Colculation purpose it is assumed that crude transfer pump & water + solid of rain case or PCV failure case 1 For Colculation purpose it is assumed that crude transfer pump & water + solid of rain case or PCV failure case 1 For PCV failure case indeleted 1 For PCV failure case line length of Blanket gas line from Battery limit to Settling / Reclaimed fluid tank assumed to be 250 meter & the same to be confirmed during detail engineerin 5 EVALUATION OF DESIGN CASES 2 Diameter 9 Hearth is 2.0 Persign (PAR) (p) / (-) 64 Kga (g), A per API (20) (clause 9.2.2) & API (20) the accumulation 1 ESF (-) 64 Kga (g) / (-) 0.56 KPa (g). 5 Et pressure of Design CASES 1 Diameter 9 Hearth is 2.0 Persign (PAR) (g) / (-) 0.56 KPa (g). 5 Et pressure of Divor off Hatch 1 22 m (rait 10 % accumulation) in the tank will be 1.81 Kpa(g) 1 Therefore volume of tail 122 m (rait 0 % accumulation) in the tank will be 1.81 Kpa(g) 1 Therefore volume of tail 122 m (rait 0 % accumulation) in the tank will be 1.81 Kpa(g) 1 Therefore volume of tail 122 m (rait 0 % accumulation) in the tank will be 1.81 Kpa(g) 1 Therefore and interesting and the cascianted fluid tank. 1 Normal interesting target is accumulated in the formed target accumulation of clause 1 (-) Normal interesting target (-) (-) 0.56 KPa (g). 1 Normal interesting target is the tex (-) (-) 0.56 K																								
Pollowing cases are to be considered: 1 2 Normal inbreathing: 2 Normal inbreathing: 3 Firm rease: 4 Firm rease: 5 Instrument & power failure case 2 ASSUMPTIONS 1 For calculation purpose it is assumed that crude transfer pump & water + solid drain are not carried 1 simultaneously 11 75 PCV 612 & 75 PCV 614 are pilot operated valve & no instrument air supply is required therefore instrum power failure case is deleted 11 PV Voicing is based on PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case which are to be confirmed during detail engineering 2 EVALUATION OF DESIGN CASES Diamotei 6.1 Height 4.16 Height 4.16 Height 4.16 Preservice volume is 2.26 7C Disamotei 1.8 (FA) (0.54 Preservice of PVV 1.6 KPa (0) / (-) 0.56 KPa (0) Tank operating temperature 2.6 (C Set pressure of PVV 1.6 KPa (0) / (-) 0.56 KPa (0) Set pressure of PVV 1.6 KPa (0) / (-) 0.56 KPa (0) A)	1	OBJE	CTIVE																					
Pollowing cases are to be considered: 1 2 Normal inbreathing: 2 Normal inbreathing: 3 Firm rease: 4 Firm rease: 5 Instrument & power failure case 2 ASSUMPTIONS 1 For calculation purpose it is assumed that crude transfer pump & water + solid drain are not carried 1 simultaneously 11 75 PCV 612 & 75 PCV 614 are pilot operated valve & no instrument air supply is required therefore instrum power failure case is deleted 11 PV Voicing is based on PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case which are to be confirmed during detail engineering 2 EVALUATION OF DESIGN CASES Diamotei 6.1 Height 4.16 Height 4.16 Height 4.16 Preservice volume is 2.26 7C Disamotei 1.8 (FA) (0.54 Preservice of PVV 1.6 KPa (0) / (-) 0.56 KPa (0) Tank operating temperature 2.6 (C Set pressure of PVV 1.6 KPa (0) / (-) 0.56 KPa (0) Set pressure of PVV 1.6 KPa (0) / (-) 0.56 KPa (0) A)		Sizinc	n of P\/\/ 8	RIOW Hat	ch for S	Sottling	tank	(T_Y	XXXI	8 P	oclai	imed	fluic	d tar)k (T			for		nro	duct	ion s	tati	
A price of binket gas control valve A Fire case Instrument & power failure case Instrument & power failure case ASSUMPTIONS I For calculation purpose it is assumed that crude transfer pump & water + solid drain are not carried i simultaneously I 725 PCV 612 & 75 PCV 614 are pilot operated valve & no instrument air supply is required therefore instrum power failure case is deleted II PVV sizing is based on PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case whichever is higher IV For PCV failure case line length of Blanket gas line from Battery limit to Settling / Reclaimed fluid tank assumed to be 250 meter & the same to be confirmed during delail engineerr Set pressure (Net use line length of Blanket gas line from Battery limit to Settling / Reclaimed fluid tank assumed to be 250 meter & the same to be confirmed during delail engineerr Set pressure (Net use 1 & 20 KPa (0) (1 < 0.5 KPa (0) As per API 620 (clause 9.2.2) & API 520 the accumulater pressure at max (bad shall not exceed 20 % above design pressure. 2 ZA (A) (D). Therefore with set pressure 165 (KPa (0) (1 < 0.5 KPa (0) (1 < 0.5 KPa (0) (2 < 0.5 KP								(1-^	^^^)			meu	nuic	u lai		-^^/	(,,,,)							
 3. Failure of blanket gis control valve 4. Frie case 5. Instrument & power failure case 2. ASSUMPTIONS 1. 75 PC/C 612, 8 75 PC/ 614 are pilot operated valve & no instrument air supply is required therefore instrum power failure case is deleted 11. 75 PC/C 612, 8 75 PC/ 614 are pilot operated valve & no instrument air supply is required therefore instrum power failure case is deleted 11. PV/ sizing is based on PC/ failure case where as Blow-off Hatch is sized for fire case or PC/ failure case where as Blow-off Hatch is sized for fire case or PC/ failure case is deleted 11. PV/ sizing is based on PC/ failure case where as Blow-off Hatch is sized for fire case or PC/ failure case is deleted 12. PV For PC/ failure case line length of Blanket gas line from Battery limit to Setting / Reclaimed fluid tank assumed to be 200 meter & the same to be confirmed during delail engineering 3. EVALUATION OF DESIGN CASES Diameter Hankies (200 meter & 16 f) meter Haggin error and the fire fore fore target of the tank is 2.0 KP3 (g) / (-) 0.5 KPa (g), As per API 620 (Glause 9.2.2) & API 520 the accumulate pressure (1.6 f) meter target or the tank is 2.0 KP3 (g) / (-) 0.5 KPa (g), Therefore with set pressure (1.6 KPa (g) / (-) 0.5 KPa (g), Therefore with set pressure (1.6 KPa (g) / (-) 0.5 KPa (g), Set pressure of Isow-off Hatch 1.8 KPa (g) Evaluation of cases A) Normal inbreathing resulting from 1.8 KPa (g) Evaluation of cases A) Normal inbreathing resulting from tom tank to pump + thermal inbreathil 2 could onlifower from settling tark to pump + thermal inbreathil 2 (Could onlifower from settling tark to pump + thermal inbreathil 2 (Could onlifower from settling tark to pump + thermal inbreathil 2 (Could onlifower from settling tark to pump + thermal inbreathil 2 (Could onlifower from settling tark to pump + thermal inbreathil 2 (Could onlifower from settling tark to pump + thermal inbreathil 2 (C																								
 4 Fire case 5 Instrument & power failure case 2 ASSUMPTIONS 1 For calculation purpose it is assumed that crude transfer pump & water + solid drain are not carried 4 simultaneously 10 75 PCV 612 & 75 PCV 614 are pilot operated valve & no instrument air supply is required therefore instrum power failure case is deleted 11 PV sizing is based on PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case where is a blow-off Hatch is sized for fire case or PCV failure case where is be confirmed during detail engineerin 2 EVALUATION OF DESIGN CASES 2 Diameter 3 EVALUATION OF DESIGN CASES 3 EVALUATION OF DESIGN CASES 3 Diameter 4 16 meter 4 16 meter 4 16 meter 4 17 Prefore vidue case in the faile with the meter 3 EVALUATION OF DESIGN CASES 3 Diameter 4 16 meter 5 18 17 PCV accumulated pressure (with 10 % accumulation in the tank will be 1.81 Kpa(i) 1 Therefore volume of tani 122 m3 TATA operating temperature 2 6 "C" 3 Et pressure of PLV 1.65 KPa (g) / (-) 0.56 KPa (g) 3 Et pressure of Blow-off Hatch 1.8 KPa (g) 4 A) Normal inbreathing requirement for tank to pump + thermal inbreathin 2 Crude oil forwater from setting transfer per Setting ta Readimed this dama in a (Water + Solid) drain. 3 (Water + Solid) drain. 4 Maximum flowrate or caude oil from from tank to pump + thermal inbreathin 3 (Water + Solid) drain. 4 Orabin as there is no cantro in setting a				e of blanke	t gas c	ontrol v	/alve																	
2 ASSUMPTIONS 1 For calculation purpose it is assumed that crude transfer pump & water + solid drain are not carried 1 simultance case is deleted 11 PVV St27 5 PCV 614 are pilot operated valve & no instrument air supply is required therefore instrum power failure case is deleted 11 PVV sizing is based on PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case whichever is higher 12 V For PCV failure case line length of Blanket gas line from Battery limit to Settling / Reclaimed fluid tank assumed to be 250 meter & the same to econfirmed during detail engineerin 3 EVALUATION OF DESIGN CASES Diameter 6.1 meter Height St pressure / Vacuur 1.65 (r) 0.54 Design pressure of the tank is 2.0 KPa (g) / (r) 0.56 Kpa (g). As per API 620 (clause 9.2.2) & API 520 the accumulating pressure at max load shind not exceed 20% above design pressure (a 2.2 Kpa (g). Therefore with set pressure 1.65 Kpa (g) for PVV, excumulated pressure (with 10 % accumulation) in the tank will be 1.81 Kpa() Therefore volume of tani 122 m3 767.4 BBL Tank operating temperature 26 "C Set pressure of Blow-off Hatch 1.8 KPa (g) Evaluation of cases A) Normal inbreasting Normal inbreasting Inbreasting Normal inbreasting Seclement fluid tank. fummy out rate is -00 m3. Fo			Fire ca	ase																				
I For calculation purpose it is assumed that crude transfer pump & water + solid drain are not carried i simultaneously II 75 PCV 612 & 75 PCV 814 are pilot operated valve & no instrument air supply is required therefore instrum power failure case is deleted. III PVV sizing is based on PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure cas where as Blow-off Hatch is sized for fire case or PCV failure cas where as Blow-off Hatch is sized for fire case or PCV failure cas where as Blow-off Hatch is sized for fire case or PCV failure cas where as Blow-off Hatch is sized for fire case or PCV failure cas where as Blow-off Hatch is sized for fire case or PCV failure cas where as Blow-off Hatch is sized for fire case or PCV failure cas where as Blow-off Hatch is size for Save for some data and the fire fore instrument of the present of the tark is 20 KPR (30) (-10.05 KPa (g), As per API 620 (clause 9.2.2) & API 520 the accumulate pressure of that is 20 KPR (30) (-10.05 KPa (g), Therefore where pressure (1.65 KPa (g) (-10.05 KPa (g), Therefore where pressure (1.65 KPa (g), Firefore where pressure (1.65 KPa (g) (-10.56 KPa (g), Eveluation of tani (1.22 m3) Tark operating temperature (2.6 ''C) Set pressure of Houter (1.8 KPa (g)) Evaluation of cases A) A) Normal inbreathing Phoreathing resulting from (1.36 KPa (g) / (-0.56 KPa (g), Clause 4.2 (Fire (0.20 KPA (g)))) For calculation purpose it is considered as 40 m3/h. Kas flowrate of crude oil from settling tank to Reclaimed fluid tank. Pump our tate is 40 m3/h. For calculation purpose it is considered as 40 m3/h. Kas flowrate of frome ontank & water + solid drain H other chare is 0 m3/h. For		5	Instrui	ment & pov	ver failt	ure cas	ie																	
simultaneously 1 11 75 PCV 612 & 75 PCV 614 are pilot operated valve & no instrument air supply is required therefore instrum power failure case is deleted 11 PVV sizing is based on PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case invelopment is higher 12 For PCV failure case line length of Blanket gas line from Battery limit to Settling / Reclaimed fluid tank assumed to be 250 meter & the same to be confirmed during detail engineerir 23 EVALUATION OF DESIGN CASES Diameter 6.1 Height 168 (P) (Height Settling / Reclaimed fluid tank assumed to be 250 meter & 168 (P) (Height Settling / Reclaimed fluid tank assumed to be 250 meter & 168 (P) (Height Settling / Reclaimed fluid tank assumed to be 250 meter & 168 (P) (Height Settling / Reclaimed fluid tank assumed to be 250 meter & 168 (P) (Height Settling / Reclaimed fluid tank assumed to avoid a 122 m3 (Port PVV, accumulated pressure (with 10 % accumulation) in the tank will be 1.81 (Pag) (Height Settling / Reclaimed fluid tank assumed to the settling / Reclaimed fluid tank assumed to rough a fluid tank assumed to rough a fluid tank through 4 line with 1 m/sec velocity is 28.5 m ² Set pressure of Brance If Tank operating Import 1 1.8 (Pag) (P) (-0.56 (Pag) (P) (D) (P) (P) (P) (P) (P) (P) (P) (P) (P) (P	2	ASSL	JMPTION	S																				
simultaneously 1 11 75 PCV 612 & 75 PCV 614 are pilot operated valve & no instrument air supply is required therefore instrum power failure case is deleted 11 PVV sizing is based on PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case invelopment is higher 12 For PCV failure case line length of Blanket gas line from Battery limit to Settling / Reclaimed fluid tank assumed to be 250 meter & the same to be confirmed during detail engineerir 23 EVALUATION OF DESIGN CASES Diameter 6.1 Height 168 (P) (Height Settling / Reclaimed fluid tank assumed to be 250 meter & 168 (P) (Height Settling / Reclaimed fluid tank assumed to be 250 meter & 168 (P) (Height Settling / Reclaimed fluid tank assumed to be 250 meter & 168 (P) (Height Settling / Reclaimed fluid tank assumed to be 250 meter & 168 (P) (Height Settling / Reclaimed fluid tank assumed to avoid a 122 m3 (Port PVV, accumulated pressure (with 10 % accumulation) in the tank will be 1.81 (Pag) (Height Settling / Reclaimed fluid tank assumed to the settling / Reclaimed fluid tank assumed to rough a fluid tank assumed to rough a fluid tank through 4 line with 1 m/sec velocity is 28.5 m ² Set pressure of Brance If Tank operating Import 1 1.8 (Pag) (P) (-0.56 (Pag) (P) (D) (P) (P) (P) (P) (P) (P) (P) (P) (P) (P		F	or calcula	ation purpo	se it is	assum	ed th	at cri	ıde tr	ansf	erpi	ump 8	& wa	ater	+ 50	lid dr	ain a	are n	ot ca	rriec	1			
power failure case is deleted III PVV sizing is based on PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case where as Blow-off Hatch is sized for Blow-off Hatch is Blow-off Hat		al and a second s																						
power failure case is deleted III PVV sizing is based on PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case where as Blow-off Hatch is sized for fire case or PCV failure case where as Blow-off Hatch is sized for Blow-off Hatch is Blow-off Hat		11 7	5 PCV 61	2 & 75 PC	V 614 :	are nilo		rator	l valv	م <u>۶</u> ۱	no in	etrun	nont	tair	SUD	ly ie	rea	ured	there	ofore	inct	rum		
whichever's higher IV For PCV failure case line length of Blanket gas line from Battery limit to Settling / Reclaimed fluid tank assumed to be 250 meter & the same to be confirmed during detail engineerr 3 EVALUATION OF DESIGN CASES Diameter 6.1 Height 4.16 meter 4.16 St pressure / Vacuum 1.65 / (*) 0.54 Design pressure of the tank is 2.0 KPa (g) / (*) 0.6 Kpa (g). As per API 620 (clause 9.2.2) & API 520 the accumulating pressure at max load shall not exceed 20 % above design pressure . 2.2 Kpa (g). Therefore with set pressure 1.65 Kpa (g) for PVV, accumulated pressure (with 10 % accumulation) in the tank will be 1.81 Kpa(r) Therefore volume of tanl 122 m3 767.4 BBL 767.4 Set pressure of PVV 1.65 KPa (g) / (*) 0.56 KPa (g, Set pressure of Blow-off Hatcer 1.8 KPa (g) Evaluation of cases 4.0 A) Normal inbreathing Inbreathing resulting trom 1. Maximum flowrate of row settling 1 reclaimed fluid tan 3 (Water + Solid) drain Flowrate of aria water from settling 1 Reclaimed fluid tank through 4* line with 1 m/sec velocity is 28.5 m3 For calculation purpose it is considered as 40 m3/hr. Max flowrate of crude oil from settling to Reclaimed fluid tank. Hump out rate is 0 m3. Simultaneousi!							. ope					Jauri		. an	Sahl	-19 13	qu							-
whichever's higher IV For PCV failure case line length of Blanket gas line from Battery limit to Settling / Reclaimed fluid tank assumed to be 250 meter & the same to be confirmed during detail engineerr 3 EVALUATION OF DESIGN CASES Diameter 6.1 Height 4.16 meter 4.16 St pressure / Vacuum 1.65 / (*) 0.54 Design pressure of the tank is 2.0 KPa (g) / (*) 0.6 Kpa (g). As per API 620 (clause 9.2.2) & API 520 the accumulating pressure at max load shall not exceed 20 % above design pressure . 2.2 Kpa (g). Therefore with set pressure 1.65 Kpa (g) for PVV, accumulated pressure (with 10 % accumulation) in the tank will be 1.81 Kpa(r) Therefore volume of tanl 122 m3 767.4 BBL 767.4 Set pressure of PVV 1.65 KPa (g) / (*) 0.56 KPa (g, Set pressure of Blow-off Hatcer 1.8 KPa (g) Evaluation of cases 4.0 A) Normal inbreathing Inbreathing resulting trom 1. Maximum flowrate of row settling 1 reclaimed fluid tan 3 (Water + Solid) drain Flowrate of aria water from settling 1 Reclaimed fluid tank through 4* line with 1 m/sec velocity is 28.5 m3 For calculation purpose it is considered as 40 m3/hr. Max flowrate of crude oil from settling to Reclaimed fluid tank. Hump out rate is 0 m3. Simultaneousi!						foilur		,l				f L let			odf					foil				
IV For PCV failure case line length of Blanket gas line from Battery limit to Settling / Reclaimed fluid tank assumed to be 250 meter & the same to be confirmed during detail engineerir 3 EVALUATION OF DESIGN CASES Diameter 6.1 meter Height 4.16 meter Set pressure of the tank is 2.0 KPa (g) / (-) 0.6 Kpa (g). As per API 620 (clause 9.2.2) & API 520 the accumulatility pressure at max load shall not exceed 20 % above design pressure is 2.2 Kpa (g). Therefore with set pressure 1.65 Kpa (g) for PVV, accumulated pressure (with 10 % accumulation) in the tank will be 1.81 Kpa(!) Therefore volume of tani 12.2 m3 Tank operating temperature 26 °C Set pressure of PVV 1.65 KPa (g) / (-) 0.56 KPa (g). Set pressure of Blow-off Hatch 1.8 KPa (g) Evaluation of cases A) A) Normal inbreathing Inbreathing resulting from 1.8 KPa (g) Flowrate of drain water from settling 1 rank to Reclaimed fluid tan 3 (Water + Sold) drain Flowrate of drain water from settling 1 Reclaimed fluid tank 3 (Water + Sold) drain Flowrate of drain water from settling 1 Reclaimed fluid tank through 4" line with 1 m/sec velocity is 28.5 m3. For calculation purpose it is considered as 40 m3/hr. Max flowrate of cude 0 if from one tank & water						iallure	case	e wne	ere as	5 BIO	w-of		un IS	s SIZ	ea to	דו דו ר	e cas	e or	PUV	allu	ne c	d		
assumed to be 250 meter & the same to be confirmed during detail engineerir 3 EVALUATION OF DESIGN CASES Diameter 6.1 meter Height 4.16 meter Set pressure (Vacuur 16.5 (·) 0.54 Design pressure of the tank is 2.0 KPa (g) / (·) 0.6 Kpa (g). As per API 620 (clause 9.2.2) & API 520 the accumulate pressure at max load shall not exceed 20 % above design pressure. 2.2 Kpa (g). Therefore with set pressure 1.85 Kpa (g) for PVV, accumulated pressure (with 10 % accumulation) in the tank will be 1.81 Kpa(!) Therefore volume of tani 122 m3 767.4 BBL Tank operating temperature 2.6 °C Set pressure of Blow-off Hatct 1.8 KPa (g) / (·) 0.56 KPa (g) Evaluation of cases Image: the same setting tank to pump + thermal inbreathili 2 Crude oil flowrate from setting trom from tank to pump + thermal inbreathili 2 Crude oil flowrate form setting tank to Reclaimed fluid tan 2 Crude oil flowrate from setting tank to Reclaimed fluid tank Thore solid drain. For calculation purpose it is considered as 40 m3/hr. Max Itowarde of the same time of the same solid drain are not carried to 3.5 For calculation purpose it is considered as 40 m3/hr. Max Itowarde of rom acetting to Reclaimed fluid tank through 4" line with 1 m/sec velocity is 28.5 m3. For calculation purpose it is considered as 40 m3/hr. Max Itowarde of rom acetting to Reclaimed fluid tank for aper acoutace transfer pump & water solid drain are not carried t																								
3 EVALUATION OF DESIGN CASES Diameter 6.1 meter Height 4.16 meter Set pressure (Vacuum 165 / (-) 0.54 Design pressure (Area and Shall not exceed 20 % above design pressure: e. 2.2 kpa (g). Therefore with set pressure (M the tank is 2.0 kpa (g). Therefore with set pressure (M to accumulate) Pressure (M te tank is 2.0 kpa (g). Are pressure (M to % accumulate) pressure (M to % accumulate) 1.85 KPa (g). For PVV accumulate) Therefore volume of tani 122 m3 Tank operating temperature 26 °C Set pressure of PVV 1.65 KPa (g) / (-) 0.56 KPa (g). Set pressure of Blow-off Hatcr 1.8 KPa (g) Evaluation of cases A) A) Normal inbreathing Inbreathing resulting fror 1. 1. Maximum flowrate from settling I cank to Reclaimed fluid tan 3 (Water + Solid) drain. For calculation purpose it is considered as 40 m3/hr. Max flowrate of rude oil from settling to Reclaimed fluid tank. Purpout rate is 40 m3. For calculation purpose it is assume that cude transfer pump can withing to Reclaimed fluid tank. Pump out rate is 40 m3. For calculation purpose it is assume that cude transfer pump can withing to Reclaimed fluid fain are not carried - Simultaneous! Pump out rate 40 M3/hr		IV F	or PCV fa	allure case o be 250 m	line ler	igth of	Bianł me to	ket ga	as line	e troi med	m Ba durir	attery na de	' lim etail	It to	Sett	iing / rir	Rec	aim	ed flu	iid ta	ank			
Diameter 6.1 meter Height 4.16 meter Set pressure / Vacuur 1.65 (-) 0.54 Design pressure of the tank is 2.0 KPa (g) / (-) 0.6 Kpa (g). As per API 620 (clause 9.2.2) & API 520 the accumulation pressure et max load shall not exceed 2.0 % above design pressure i.e. 2.2 Kpa (g). Therefore with set pressure interpressure (with 10 % accumulation) in the tank will be 1.81 Kpa(i) Therefore volume of tanl 122 m3 Tank operating temperature 2.6 °C Set pressure of Blow-off Hatch 1.85 KPa (g) / (-) 0.56 KPa (g) Set pressure of Blow-off Hatch 1.8 KPa (g) Evaluation of cases A) Normal inbreathing Inbreathing resulting from 1. Maximum flowrate of orude oil from from tank to pump + thermal inbreathin 2. Crude oil flowrate from settling 1 Reclaimed fluid tant 3. (Water + Solid) drain. Flowrate of drain water from settling / Reclaimed fluid tant 3. (Water + Solid) drain. For calculation purpose it is assume that crude transfer pump activity in m/sec valocity is 28.5 m3. For calculation purpose it is assume that crude transfer pump activity in m/sec valocity is 28.5 m3. For calculation purpose it is assume that crude transfer pump activity of trans settling in the claimed fluid tank. Pump out cate is 40 m3. F														2g										
Diameter 6.1 meter Height 4.16 meter Set pressure / Vacuur 1.65 (-) 0.24 Design pressure of the tank is 2.0 KPa (g) / (-) 0.6 Kpa (g). As per API 620 (clause 9.2.2) & API 520 the accumulation pressure at max load shall not exceed 20 % above design pressure i.e. 2.2 Kpa (g). Therefore with set pressure 1.65 Kpa (g) for PVV, accumulated pressure (with 10 % accumulation) in the tank will be 1.81 Kpa(t) Therefore volume of tanl 122 m3 Tank operating temperature 26 °C Set pressure of PVV 1.65 KPa (g) / (-) 0.56 KPa (g) Set pressure of Blow-off Hatct 1.8 KPa (g) Evaluation of cases A) A) Normal inbreathing Inbreathing resulting from 1.48 KPa (g) Inbreathing resulting from 1.48 KPa (g) Rowrate from settling / Reclaimed fluid tank 1.04 ms/mt 3 Water + Solid) drain For ralculation purpose it is considered as 40 m3/m. Max flowrate of orude oil from settling to reclaimed fluid tank 1.0 ms/mt 1.64 ms/mt Set meter + solid) drain from terms with a m/sec velocity is 28.5 m3. For calculation purpose it is assume that crude transfer purpose and tank. Purpo out rate is 40 m3. For calculation purpose it is assume that crude transfer purpose transet purpuse to calcumed flu	2	EVAL			NCAS	FS							_								-			
Height 4.16 meter Set pressure / Vacuum 1.65 / (-) 0.54 Design pressure of the tank is 2.0 KPa (g) / (-) 0.6 Kpa (g). As per API 620 (clause 9.2.2) & API 520 the accumulative pressure at max load shall not exceed 20 % above design pressure. 1.65 Kpa (g) for PVV, accumulated pressure (with 10 % accumulation) in the tank will be 1.81 Kpa(; Therefore volume of tanl 122 Tank operating temperature 26 Set pressure of PVV 1.65 KPa (g) / (-) 0.56 KPa (g) Set pressure of Blow-off Hatct 1.8 KPa (g) Evaluation of cases	3					,J		+++	++-	+	++				++	+	+	+			+	++		
Design pressure of the tank is 2.0 KPa (g) / (·) 0.6 Kpa (g). As per API 620 (clause 92.2) & API 520 the accumulated pressure (1.65 Kpa (g) for PVV, accumulated pressure (with 10 % accumulation) in the tank will be 1.81 Kpa(r) Therefore volume of tanl 122 m3 Tank operating temperature 26 °C Set pressure of PVV 1.65 KPa (g) / (·) 0.56 KPa (g) Set pressure of PVV Set pressure of Blow-off Hatct 1.8 KPa (g) Evaluation of cases A) Normal inbreathing Inbreathing resulting form 1. Maximum flowrate of crude oil from from tank to pump + thermal inbreathii 2 Crude oil flowrate from settling tank to Reclaimed fluid tank Iporrate of drain water from settling / Reclaimed fluid tank through 4° line with 1 m/sec velocity is 28.5 m3 For calculation purpose it is considered as 40 m3/hr. Max flowrate of crude oil from settling to Reclaimed fluid tank. Pump out rate is 40 m3. For calculation purpose it is assume that crude transfer pump & water + solid drain are not carried (Simultaneously. However crude transfer pump & water + solid drain are not carried (Simultaneously. However crude transfer pump & tank to pupps is equivalent to 0.94 nm3/hr of air for escubic meter of liquid withforkm. However for calculation purpose it is aconsidered to be 1 m3/hr of air eeccubic meter of liquid withforkm. However for 20 calculate as 4.32.2' Therefore inbreathing requirements for operating the pumps is equivalent to 0.94 nm3/hr of air eeccubic meter of liquid withforkmar			Diameter			6.1	me	eter																
Design pressure of the tank is 2.0 KPa (g) / (·) 0.6 Kpa (g). As per API 620 (clause 92.2) & API 520 the accumulated pressure (1.65 Kpa (g) for PVV, accumulated pressure (with 10 % accumulation) in the tank will be 1.81 Kpa(r) Therefore volume of tanl 122 m3 Tank operating temperature 26 °C Set pressure of PVV 1.65 KPa (g) / (·) 0.56 KPa (g) Set pressure of PVV Set pressure of Blow-off Hatct 1.8 KPa (g) Evaluation of cases A) Normal inbreathing Inbreathing resulting form 1. Maximum flowrate of crude oil from from tank to pump + thermal inbreathii 2 Crude oil flowrate from settling tank to Reclaimed fluid tank Iporrate of drain water from settling / Reclaimed fluid tank through 4° line with 1 m/sec velocity is 28.5 m3 For calculation purpose it is considered as 40 m3/hr. Max flowrate of crude oil from settling to Reclaimed fluid tank. Pump out rate is 40 m3. For calculation purpose it is assume that crude transfer pump & water + solid drain are not carried (Simultaneously. However crude transfer pump & water + solid drain are not carried (Simultaneously. However crude transfer pump & tank to pupps is equivalent to 0.94 nm3/hr of air for escubic meter of liquid withforkm. However for calculation purpose it is aconsidered to be 1 m3/hr of air eeccubic meter of liquid withforkm. However for 20 calculate as 4.32.2' Therefore inbreathing requirements for operating the pumps is equivalent to 0.94 nm3/hr of air eeccubic meter of liquid withforkmar			et pressu	re / Vacuu	r i	4.16 1.65 / (me -) 0.5	eter 54			+									+				
1.65 Kpa (g) for PVV, accumulated pressure (with 10 % accumulation) in the tank will be 1.81 Kpa(: Therefore volume of tan 122 m3 Tank operating temperature 26 °C Set pressure of PVV 1.65 KPa (g) / (-) 0.56 KPa (g) Set pressure of Blow-off Hatct 1.8 KPa (g) Evaluation of cases		Desig	n pressur	e of the tar	nk is 2.0) KPa ((g) / (-) 0.6	6 Кра	(g).	As p	er Al	PI 62	20 (claus	se 9.2	2.2)	& AF	PI 520) the	acc	umul	at	
Therefore volume of tanl 122 m3 Tank operating temperature 26 °C Set pressure of PVV 1.65 KPa (g) / (-) 0.56 KPa (g) Set pressure of Blow-off Hatct 1.8 KPa (g) Evaluation of cases		press	ure at max	x load shal	l not ex	ceed 2	20 %	abov	e des	ian r	oress	surei.	.e. 2	.2 K	ba (a). Tl	here	fore	with s	set p	ress	ure		_
Tank operating temperature 26 "C Set pressure of PVV 1.65 KPa (g) / (-) 0.56 KPa (g) Set pressure of Blow-off Hatcr 1.8 KPa (g) Evaluation of cases		1.00 P	νρα (y) 101		unuale	su pres	Sure	(with	107		Juiiil	inatio	11) II	r u le			50	.01	ivha(+		+++		+
Tank operating temperature 26 *C Set pressure of PVV 1.65 KPa (g) / (-) 0.56 KPa (g) Set pressure of Blow-off Hatcr 1.8 KPa (g) Evaluation of cases		There	fore volur	ne of tanl																				
Set pressure of PVV 1.65 KPa (g) / (-) 0.56 KPa (g) Set pressure of Blow-off Hatcr 1.8 KPa (g) Evaluation of cases		Tank	operating	temperatu																				
Set pressure of Blow-off Hatct 1.8 KPa (g) Evaluation of cases A) Normal inbreathing Inbreathing resulting from 1. Maximum flowrate of crude oil from from tank to pump + thermal inbreathin 2 Crude oil flowrate from settling tank to Reclaimed fluid tan 3 (Water + Solid) drain. Flowrate of drain water from settling / Reclaimed fluid tank through 4* line with 1 m/sec velocity is 28.5 m3 For calculation purpose it is considered as 40 m3/hr, Max flowrate of crude oil from settling to Reclaimed fluid tank. Pump out rate is 40 m3. For calculation purpose it is assume that crude transfer pump & water +solid drain are not carried i Simultaneously. However crude transfer pump as water +solid drain are not carried i Yimultaneously. However crude transfer pump can withdraw crude oil from one tank & water +solid drain fr other tank can be carried out simultaneously. Pump out rate 40 Nm3/hr Therefore inbreathing requirements for operating the pumps is equivalent to 0.94 nm3/hr of air for ee cubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.' Therefore amount of inbreathing a 40 Nm3/hr Inbreathing resulting from thermal expension / contraction is calculated as per API 20 As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day.																								
Evaluation of cases A) Normal inbreathing Inbreathing resulting fror 1. Maximum flowrate of crude oil from from tank to pump + thermal inbreathii 2 Crude oil flowrate from settling tank to Reclaimed fluid tan 3 (Water + Solid) drain. Flowrate of drain water from settling / Reclaimed fluid tank through 4" line with 1 m/sec velocity is 28.5 m3 For calculation purpose it is considered as 40 m3/hr. Max flowrate of crude oil from settling to Reclaimed fluit is 40 m3/hr as there is no control valve on line from Settling to Reclaimed fluid tank. Pump out rate is 40 m3/. For calculation purpose it is assume that crude transfer pump & water +solid drain are not carried (Simultaneously. However crude transfer pump as water +solid drain are not carried (Simultaneously. However crude transfer pump as is equivalent to 0.94 nm3/hr of air for eecubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.' Pump out rate 40 Nm3/hr Therefore amount of inbreathing a 40 Nm3/hr Inbreathing resulting from thermal expension / contraction is calculated as per API 20! As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day.		Set pr	ressure of	PVV		1.6	55 KF	۶a (g) / (-)	0.56	KPa	a (g)												
 A) Normal inbreathing Inbreathing resulting from Maximum flowrate of crude oil from from tank to pump + thermal inbreathin 2 Crude oil flowrate from settling tank to Reclaimed fluid tan 3 (Water + Solid) drain. Flowrate of drain water from settling / Reclaimed fluid tank through 4" line with 1 m/sec velocity is 28.5 m3 For calculation purpose it is considered as 40 m3/hr. Max flowrate of crude oil from settling to Reclaimed fluid tank. Pump out rate is 40 m3. For calculation purpose it is assume that crude transfer pump & water +solid drain are not carried (Simultaneous). However crude transfer pump as water +solid drain are not carried (Simultaneous). However crude transfer pumps is equivalent to 0.94 nm3/hr of air for execubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.' Therefore inbreathing requirements for operating the pumps is equivalent to 0.94 nm3/hr of air each cubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.' Therefore amount of inbreathing a 40 Nm3/hr Inbreathing resulting from thermal expension / contraction is calculated as per API 20! As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day.		Set pr	ressure of	Blow-off H	latch	1.8	3 KPa	a (g)														+		
 A) Normal inbreathing Inbreathing resulting from Maximum flowrate of crude oil from from tank to pump + thermal inbreathin 2 Crude oil flowrate from settling tank to Reclaimed fluid tan 3 (Water + Solid) drain. Flowrate of drain water from settling / Reclaimed fluid tank through 4" line with 1 m/sec velocity is 28.5 m3 For calculation purpose it is considered as 40 m3/hr. Max flowrate of crude oil from settling to Reclaimed fluid tank. Pump out rate is 40 m3. For calculation purpose it is considered as 40 m3/hr. Max flowrate of crude oil from settling to Reclaimed fluid tank. Pump out rate is 40 m3. For calculation purpose it is assume that crude transfer pump & water +solid drain are not carried (Simultaneously. However crude transfer pump as water +solid drain are not carried (Simultaneously. However crude transfer pump is equivalent to 0.94 nm3/hr of air for execubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.' Therefore inbreathing requirements for operating the pumps is equivalent to 0.94 nm3/hr of air for execubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.' Therefore amount of inbreathing a 40 Nm3/hr Inbreathing resulting from thermal expension / contraction is calculated as per API 20! As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day.		Eve	aluation	of cases									_											_
Inbreathing resulting from 1. Maximum flowrate of crude oil from from tank to pump + thermal inbreathin 2. Crude oil flowrate from settling tank to Reclaimed fluid tan 3. (Water + Solid) drain. Flowrate of drain water from settling / Reclaimed fluid tank through 4" line with 1 m/sec velocity is 28.5 m3 For calculation purpose it is considered as 40 m3/hr. Max flowrate of crude oil from settling to Reclaimed fluid tank. Pump out rate is 40 m3. For calculation purpose it is assume that crude transfer pump & water +solid drain are not carried (Simultaneously. However crude transfer pump a water +solid drain are not carried (Simultaneously. However crude transfer pump is sequivalent to 0.94 nm3/hr of air for eacubic meter of liquid withdrawn. However for calculation purpose it is considered to be 1 m3/hr of air for eacubic meter of liquid withdrawn. Refer API 2000 clause 4.3.2.' Therefore amount of inbreathing a 40 Nm3/hr Inbreathing resulting from thermal expension / contraction is calculated as per API 20! As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day.				1 Cases							+													
 1. Maximum flowrate of crude oil from from tank to pump + thermal inbreathil 2. Crude oil flowrate from settling tank to Reclaimed fluid tan 3. (Water + Solid) drain. Flowrate of drain water from settling / Reclaimed fluid tank through 4" line with 1 m/sec velocity is 28.5 m3 For calculation purpose it is considered as 40 m3/hr. Max flowrate of crude oil from settling to Reclaimed fluid tank. Pump out rate is 40 m3. For calculation purpose it is assume that crude transfer pump & water +solid drain are not carried to a same that crude transfer pump can withdraw crude oil from one tank & water +solid drain fr other tank can be carried out simultaneously. Pump out rate 40 Nm3/hr Pump out rate 40 Nm3/hr Therefore inbreathing requirements for operating the pumps is equivalent to 0.94 nm3/hr of air for eac cubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.' Therefore amount of inbreathing a 40 Nm3/hr Inbreathing resulting from thermal expension / contraction is calculated as per API 201 As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr = 1538.4 sm3 / day'. 		A	() Norma	al inbreathi	ng																			
 1. Maximum flowrate of crude oil from from tank to pump + thermal inbreathil 2. Crude oil flowrate from settling tank to Reclaimed fluid tan 3. (Water + Solid) drain. Flowrate of drain water from settling / Reclaimed fluid tank through 4" line with 1 m/sec velocity is 28.5 m3 For calculation purpose it is considered as 40 m3/hr. Max flowrate of crude oil from settling to Reclaimed fluid tank. Pump out rate is 40 m3. For calculation purpose it is assume that crude transfer pump & water +solid drain are not carried to a same that crude transfer pump can withdraw crude oil from one tank & water +solid drain fr other tank can be carried out simultaneously. Pump out rate 40 Nm3/hr Pump out rate 40 Nm3/hr Therefore inbreathing requirements for operating the pumps is equivalent to 0.94 nm3/hr of air for eac cubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.' Therefore amount of inbreathing a 40 Nm3/hr Inbreathing resulting from thermal expension / contraction is calculated as per API 201 As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr = 1538.4 sm3 / day'. 			Inbrea	athing resu	ltina fro	m																		
3 (Water + Solid) drain. Flowrate of drain water from settling / Reclaimed fluid tank through 4" line with 1 m/sec velocity is 28.5 m3 For calculation purpose it is considered as 40 m3/hr. Max flowrate of crude oil from settling to Reclaimed fluis 40 m3/hr as there is no control valve on line from Settling to Reclaimed fluid tank. Pump out rate is 40 m3. For calculation purpose it is assume that crude transfer pump & water +solid drain are not carried (Simultaneously. However crude transfer pump can withdraw crude oil from one tank & water +solid drain fr other tank can be carried out simultaneously. Pump out rate 40 Nm3/hr Therefore inbreathing requirements for operating the pumps is equivalent to 0.94 nm3/hr of air for eactubic meter of liquid withdrawn. However for calculation purpose it is considered to be 1 m3/hr of air each cubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.' Therefore amount of inbreathing a 40 Nm3/hr Inbreathing resulting from thermal expension / contraction is calculated as per API 20i As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day.			1. Max	kimum flow	rate of	crude	oil fro	om fro	om ta	nk to	o pur	np +	ther	rmal	inbr	eathi	i							
Flowrate of drain water from settling / Reclaimed fluid tank through 4" line with 1 m/sec velocity is 28.5 m3 For calculation purpose it is considered as 40 m3/hr. Max flowrate of crude oil from settling to Reclaimed fluit is 40 m3/hr as there is no control valve on line from Settling to Reclaimed fluid tank. Pump out rate is 40 m3. For calculation purpose it is assume that crude transfer pump & water +solid drain are not carried (Simultaneously. However crude transfer pump can withdraw crude oil from one tank & water +solid drain fr other tank can be carried out simultaneously. Pump out rate 40 Nm3/hr Therefore inbreathing requirements for operating the pumps is equivalent to 0.94 nm3/hr of air for eacubic meter of liquid withdrawn. However for calculation purpose it is considered to be 1 m3/hr of air each cubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.'') Therefore amount of inbreathing a 40 Nm3/hr Inbreathing resulting from thermal expension / contraction is calculated as per API 20! As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day'.							ng ta	nk to	Recl	aime	ed flu	iid ta	n											
For calculation purpose it is considered as 40 m3/hr. Max flowrate of crude oil from settling to Reclaimed fluits 40 m3/hr as there is no control valve on line from Settling to Reclaimed fluid tank. Pump out rate is 40 m3. For calculation purpose it is assume that crude transfer pump & water +solid drain are not carried (Simultaneously. However crude transfer pump can withdraw crude oil from one tank & water +solid drain fr other tank can be carried out simultaneously Pump out rate 40 Nm3/hr Therefore inbreathing requirements for operating the pumps is equivalent to 0.94 nm3/hr of air for eacubic meter of liquid withdrawn. However for calculation purpose it is considered to be 1 m3/hr of air each cubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.' Therefore amount of inbreathing a 40 Nm3/hr Inbreathing resulting from thermal expension / contraction is calculated as per API 200 As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day.			, ,		, 					+														+
is 40 m3/hr as there is no control valve on line from Settling to Reclaimed fluid tank. Pump out rate is 40 m3, For calculation purpose it is assume that crude transfer pump & water +solid drain are not carried (Simultaneously. However crude transfer pump can withdraw crude oil from one tank & water +solid drain fr other tank can be carried out simultaneously. Pump out rate 40 Nm3/hr Therefore inbreathing requirements for operating the pumps is equivalent to 0.94 nm3/hr of air for ea cubic meter of liquid withdrawn. However for calculation purpose it is considered to be 1 m3/hr of air each cubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.' Therefore amount of inbreathing a 40 Nm3/hr Inbreathing resulting from thermal expension / contraction is calculated as per API 20 As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day.																								
For calculation purpose it is assume that crude transfer pump & water +solid drain are not carried (Simultaneously. However crude transfer pump can withdraw crude oil from one tank & water +solid drain fr other tank can be carried out simultaneously Pump out rate 40 Nm3/hr Therefore inbreathing requirements for operating the pumps is equivalent to 0.94 nm3/hr of air for eac cubic meter of liquid withdrawn. However for calculation purpose it is considered to be 1 m3/hr of air each cubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.' Therefore amount of inbreathing a 40 Nm3/hr Inbreathing resulting from thermal expension / contraction is calculated as per API 20! As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day'.																								
other tank can be carried out simultaneous! Pump out rate 40 Nm3/hr Therefore inbreathing requirements for operating the pumps is equivalent to 0.94 nm3/hr of air for eacubic meter of liquid withdrawn. However for calculation purpose it is considered to be 1 m3/hr of air each cubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.' Therefore amount of inbreathing a 40 Nm3/hr Inbreathing resulting from thermal expension / contraction is calculated as per API 20 As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day.			For ca	lculation p	urpose	it is as	sume	e that	t crud	e tra	insfe	r pun	np 8	& wa	ter +	-solic	l dra	in ar	e not	carr	ied (
Pump out rate 40 Nm3/hr Therefore inbreathing requirements for operating the pumps is equivalent to 0.94 nm3/hr of air for eacluation purpose it is considered to be 1 m3/hr of air each cubic meter of liquid withdrawn. However for calculation purpose it is considered to be 1 m3/hr of air each cubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.' Therefore amount of inbreathing a 40 Nm3/hr Inbreathing resulting from thermal expension / contraction is calculated as per API 20 As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day.			Simult other	aneously. tank can be	Howev e carrie	er crud d out s	ie tra	nster aneo	pum	p cai	n wit	ndrav	w cr	ude	OII ŤI	om c	one t	ank	& wa	ter +	SOLIC	ı drai	n tr	
Therefore inbreathing requirements for operating the pumps is equivalent to 0.94 nm3/hr of air for ec cubic meter of liquid withdrawn. However for calculation purpose it is considered to be 1 m3/hr of air each cubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.' Therefore amount of inbreathing a 40 Nm3/hr Inbreathing resulting from thermal expension / contraction is calculated as per API 200 As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day'.																								
cubic meter of liquid withdrawn. However for calculation purpose it is considered to be 1 m3/hr of air each cubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.' Therefore amount of inbreathing a 40 Nm3/hr Inbreathing resulting from thermal expension / contraction is calculated as per API 200 As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day'.			P	ump out ra		ng roc		nonto	for c	40	Nm3	s/hr				ivola	nt to		1 nm'	3/hr	of	for	25	
each cubic meter of liquid withdrawn. (Refer API 2000 clause 4.3.2.' Therefore amount of inbreathing a 40 Nm3/hr Inbreathing resulting from thermal expension / contraction is calculated as per API 200 As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day.				ubic meter	of liqui	d withd	Irawn	ients i. Hov	Nevel	for	calcu	ulatio	n pu	urpo	se it	is co	ni to nsid	ered	+ mitic	e 1 n	n3/h	r of a	ec lir	
Inbreathing resulting from thermal expension / contraction is calculated as per API 20 As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day.			e	ach cubic r	neter o	f liquid	with	draw		efer /	API 2	2000										-		
As per table 2B for 122 m3 of tank capacity thermal inbreathing is 20.6 Nm3/hr Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day.			<u> </u>	neretore a	mount	ot indre	atnir	ig a		40	inm3	ynr			$\left \cdot \right $					+				
Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day.			l Ir	breathing	resultin	ig from	therr	mal e	xpen	sion	/ cor	ntract	tion	is ca	alcul	ated	as p	er A	PI 20					
Therefore normal inbreathing rate is 40 + 20.6 = 60.6 Nm3/hr = 64.1 sm3/hr = 1538.4 sm3 / day.																								
			A	s per table	2B for	122 m	3 of t	ank o	capac	ity th	nerm	al int	orea	thin	g is :	20.6	Nm3	/hr						
			+ + + +	herefora n	ormali	hreath	ning r	ato in	: 40 .	. 20 /	6 – e	SO 6 N		۱/hr	- 64	1	13/h*	_ 1	538 /	em'	יה / ג	21/2		
			+			wieati	ing f		, 40 +	20.0	ບ ≕ ເ 	0.0 ľ	ALLIS	///// 3	- 04	. 1 311		- 13	.50.4	3110	ui 	م ۲.		
								+++																
	 		<u> </u>							<u>_</u>	<u>_</u>					<u> </u>				<u>_</u>				4

TITLE	CALCULATION OF CAPACIT PROVIDED ON SETTLING &		CUUM RELIEF VALVE & BLOW-OFF	
JOB NO	DEPART	MENT PROCESS	AUTHOR	DATE
<u> </u>				
	B) Normal Outbreathing			
			wrate of liquid from road tanker i	nto the tar
	Therefore outbrea	athing requirement due to flo	m3/hr ow of liquid into the tank is 2.02	m3/hr of air per cubic
		er API 2000 clause 4.3.2.2 r flowrate from tank during c	outbreathing is 40 x 2.02 = 81 m	3/1
			/ contraction is calculated as per	
	As per table 2B fo	or 122 m3 of tank capacity t	hermal outbreathing is 20.6 m3/	
	Therefore normal or	utbreathing rate is 81 + 20.6	6 = 101.6 Nm3/hr = 107.4 sm3/hr	r = 2577.6 sm3/da
	C) Failure of Blanket gas	control valve		
	Battery limit pressu	e of Blanket gas is 3.51 bar	r a. This pressure is reduced by	using self actuated control val
		ss self actuated control valv		
	Refer for inlet gas li	ne size		
	Failure of PCV will car	ise higher gas flowrate thro	ugh PVV. Considering sonic vel	ocity through 2" line provic
	upstream of PCV, max	kimum flowrate through PV	√ is 1000 kg / hr. (Refer ESI outp	out, attachment
			onsidered as 250 meter from tie i e confirmed during detail engi	
	Density = 1 x 1	8.94 ÷ (0.08206 x 288.6 .7997 kg / sm3		
		1251.0 sm3 / hr.		
	Refer Hysis output for	viscosity calculation & ESI	output for flowrate at sonic veloc	sity (attachment
	With 25 % margin on f	IOWRATES		
	Vol flowrate =	: 1565.0 sm3 / hr.		
	PCV failure can occur	e during normal outbreathin	g also. Therefore outbreathing c	uring PCV failure case
	Normal outbreath	ing + PCV failure case = 15	65 + 108 = 1673 sm3 / ł	
	D) FIRE CASE Set pressure of blow-o	off Hatch = 1.8 KPa (g). The	erefore for fire case with 21 % ac	cumulation, maximum pressu
		1= 2.18 KPa (g) which is les /V during fire case is calcul		
	Q = 199300 x F x			
	Surface area of ta	ank / = 3.142 x 6.1 x 4	4.16	
		= 79.73 m ²		
	0 224200 × 1 ×	70 000 500		
	Q = 224200 x 1 x Q = 2674.05 KWa			
	As latent heat of va	courization for crude oil = 8^{4}	49.2 Kj / Kg. (refer attachment 2	stream No 43). Theref
	L = 849.2 KJ / K	3		
	T = 34.1°C			
	T = 307.1°K			
	M = 26.06 (Re	fer Hysis output attachmen	t 2	
	Therefore flowret	e through blow-off hatc		
+		.55 x (QF÷L) x (T÷M)^0.5 .55 x (2674.05 x 1 ÷ 849.4)	x (307 1 ÷ 26 06)^0 5	
		26.92 Nm3/hr		
	With 25 % margir	on flowrates		
	= 119	008.6 Nm3/hr		
		100 am2/br		
	= 120)00 sm3/hr		
				PAGE NO 2